

WASTE STREAM	3J24	Neutron Scatter Plugs
---------------------	-------------	------------------------------

SITE Dungeness B

SITE OWNER EDFE NGL

WASTE CUSTODIAN EDFE NGL

WASTE TYPE ILW; SPD3

WASTE VOLUMES

		Reported
Stocks:	At 1.4.2019.....	25.2 m ³
Future arisings -	1.4.2019 - 31.3.2028.....	14.4 m ³
	1.4.2028 - 31.3.2114.....	0 m ³
	1.4.2114 - 31.3.2118.....	81.6 m ³
Total future arisings:		96.0 m ³
Total waste volume:		121.2 m ³

Comment on volumes: Arisings are estimated on current rate of arising during operations and total arising during decommissioning. The current rate of arising is reliant on successful reconditioning for return to service of some components.

Uncertainty factors on volumes:	Stock (upper):	x 1.25	Arisings (upper)	x 1.75
	Stock (lower):	x 0.75	Arisings (lower)	x 0.25

WASTE SOURCE Stainless steel components resulting from discarded NSPs.

PHYSICAL CHARACTERISTICS

General description: Each NSP is approx. 2.5m long, 220mm diameter and 0.5 Te weight, thus one NSP has volume of ~0.1m3. Each assembly consists of cruciform four-start helically shaped Neutron Scatter Plug capable of sliding axially within an all-welded containment envelope comprising an annulus sleeve and tube assembly.

Physical components (%wt): Stainless Steel (100%).

Sealed sources: The waste does not contain sealed sources.

Bulk density (t/m³): ~5

Comment on density: -

CHEMICAL COMPOSITION

General description and components (%wt): Stainless steel (100%)

Chemical state: Neutral

Chemical form of radionuclides:
 H-3: Tritium in material
 C-14: Some contamination by graphite
 Cl-36: Not assessed
 Se-79: Not expected to be significant
 Tc-99: Not expected to be significant
 I-129: Not expected to be significant
 Ra: Not expected to be significant
 Th: Not expected to be significant
 U: Not expected to be significant
 Np: Not expected to be significant
 Pu: Not expected to be significant

Metals and alloys (%wt): -

Stainless steel.....	~100.0	Stainless Steel forgings to BS EN 10222-5 Grade 1.4301
Other ferrous metals.....	0	
Iron.....	0	
Aluminium.....	0	
Beryllium.....	0	
Cobalt.....	0	
Copper.....	0	

WASTE STREAM**3J24****Neutron Scatter Plugs**

	Lead.....	0
	Magnox/Magnesium.....	0
	Nickel.....	0
	Titanium.....	0
	Uranium.....	0
	Zinc.....	0
	Zircaloy/Zirconium.....	0
	Other metals.....	0
Organics (%wt):	-	
	Total cellulose.....	0
	Paper, cotton.....	0
	Wood.....	0
	Halogenated plastics	0
	Total non-halogenated plastics.....	0
	Condensation polymers.....	0
	Others.....	0
	Organic ion exchange materials....	0
	Total rubber.....	0
	Halogenated rubber	0
	Non-halogenated rubber.....	0
	Hydrocarbons.....	0
	Oil or grease	
	Fuel.....	
	Asphalt/Tarmac (cont.coal tar)...	
	Asphalt/Tarmac (no coal tar)....	
	Bitumen.....	
	Others.....	
	Other organics.....	0
Other materials (%wt):	-	
	Inorganic ion exchange materials.	0
	Inorganic sludges and flocs.....	0
	Soil.....	0
	Brick/Stone/Rubble.....	0
	Cementitious material.....	0
	Sand.....	0
	Glass/Ceramics.....	0
	Graphite.....	TR
	Desiccants/Catalysts.....	0
	Asbestos.....	0
	Non/low friable.....	
	Moderately friable.....	
	Highly friable.....	

WASTE STREAM	3J24	Neutron Scatter Plugs
---------------------	-------------	------------------------------

	Free aqueous liquids.....	0
	Free non-aqueous liquids.....	0
	Powder/Ash.....	0
Inorganic anions (%wt):	-	
	Fluoride.....	0
	Chloride.....	0
	Iodide.....	0
	Cyanide.....	0
	Carbonate.....	0
	Nitrate.....	0
	Nitrite.....	0
	Phosphate.....	0
	Sulphate.....	0
	Sulphide.....	0
Materials of interest for waste acceptance criteria:	-	
	Combustible metals.....	0
	Low flash point liquids.....	0
	Explosive materials.....	0
	Phosphorus.....	0
	Hydrides.....	0
	Biological etc. materials.....	0
	Biodegradable materials.....	0
	Putrescible wastes.....	0
	Non-putrescible wastes.....	0
	Corrosive materials.....	0
	Pyrophoric materials.....	0
	Generating toxic gases.....	0
	Reacting with water.....	0
	Active particles.....	P
	Soluble solids as bulk chemical compounds.....	0
Hazardous substances / non hazardous pollutants:	-	
	Acrylamide.....	NE
	Benzene.....	NE
	Chlorinated solvents.....	NE
	Formaldehyde.....	NE
	Organometallics.....	NE
	Phenol.....	NE
	Styrene.....	NE
	Tri-butyl phosphate.....	NE
	Other organophosphates.....	NE

WASTE STREAM**3J24****Neutron Scatter Plugs**

Vinyl chloride.....	NE
Arsenic.....	NE
Barium.....	NE
Boron.....	NE
Cadmium.....	NE
Caesium.....	NE
Selenium.....	NE
Chromium.....	NE
Molybdenum.....	NE
Thallium.....	NE
Tin.....	NE
Vanadium.....	NE
Mercury compounds.....	NE
Others.....	NE
Electronic Electrical Equipment (EEE)	
EEE Type 1.....	0
EEE Type 2.....	0
EEE Type 3.....	0
EEE Type 4.....	0
EEE Type 5.....	0
Complexing agents (%wt):	Not yet determined
EDTA.....	NE
DPTA.....	NE
NTA.....	NE
Polycarboxylic acids.....	NE
Other organic complexants.....	NE
Total complexing agents.....	NE

PACKAGING AND CONDITIONING

Conditioning method:	The waste is not expected to be supercompacted. It will be placed in baskets in the waste packages, and is assumed to be encapsulated.
Plant Name:	-
Location:	-
Plant startup date:	85 years after reactor shut-down
Total capacity (m ³ /y incoming waste):	~5000.0
Target start date for packaging this stream:	-
Throughput for this stream (m ³ /y incoming waste):	~
Other information:	-

WASTE STREAM 3J24 Neutron Scatter Plugs

Likely container type:	Container	Waste packaged (%vol)	Waste loading (m ³)	Payload (m ³)	Number of packages
	4m box (100mm concrete shielding)	100.0	4.9	14.3	25

Likely container type comment: -

Range in container waste volume: -

Other information on containers: Stainless Steel.

Likely conditioning matrix: -

Other information: -

Conditioned density (t/m³): ~3.43

Conditioned density comment: Assumes waste will be encapsulated, matrix would be likely to be BFS/OPC.

Other information on conditioning: The waste will be in baskets placed in the waste packages. Baskets of different Stage 3 ILW wastes may be in the same waste package.

Opportunities for alternative disposal routing: No

Treatment	Stream volume (%)	Comment
-	-	-

RADIOACTIVITY

Source: Activation of nuclides within the steel will be the main sources of activity.

Uncertainty: Specific activity is a function of station operating history. The values quoted are indicative of the activities that might be expected.

Definition of total alpha and total beta/gamma: Where totals are shown on the table of radionuclide activities they are the sums of the listed alpha or beta/gamma emitting radionuclides plus 'other alpha' or 'other beta/gamma'.

Measurement of radioactivities: Data is estimated for certain significant activation nuclides based on time in service. Other nuclides likely to be present are inferred from MAC & Fuel Stringer Debris waste stream 3J27.

Other information: -

WASTE STREAM

3J24

Neutron Scatter Plugs

Nuclide	Mean radioactivity, TBq/m ³				Nuclide	Mean radioactivity, TBq/m ³			
	Waste at 1.4.2019	Bands and Code	Future arisings	Bands and Code		Waste at 1.4.2019	Bands and Code	Future arisings	Bands and Code
H 3		6		6	Gd 153				
Be 10					Ho 163				
C 14		6		6	Ho 166m				
Na 22		4		4	Tm 170				
Al 26		4		4	Tm 171				
Cl 36		6		6	Lu 174				
Ar 39					Lu 176				
Ar 42					Hf 178n				
K 40					Hf 182				
Ca 41		6		6	Pt 193				
Mn 53					Tl 204				
Mn 54		7		7	Pb 205				
Fe 55	6.00E+00	DD 2	1.43E+01	DD 2	Pb 210				
Co 60	1.72E+00	DD 2	1.22E+00	DD 2	Bi 208				
Ni 59	6.75E-02	DD 2	6.75E-02	DD 2	Bi 210m				
Ni 63	7.00E+00	DD 2	4.80E+00	DD 2	Po 210				
Zn 65		6		6	Ra 223				
Se 79					Ra 225				
Kr 81					Ra 226				
Kr 85					Ra 228				
Rb 87					Ac 227				
Sr 90					Th 227				
Zr 93					Th 228				
Nb 91					Th 229				
Nb 92					Th 230				
Nb 93m		6		6	Th 232				
Nb 94		6		6	Th 234				
Mo 93		6		6	Pa 231				
Tc 97					Pa 233				
Tc 99					U 232				
Ru 106					U 233				
Pd 107					U 234				
Ag 108m		6		6	U 235				
Ag 110m		6		6	U 236				
Cd 109		6		6	U 238				
Cd 113m					Np 237				
Sn 119m					Pu 236				
Sn 121m					Pu 238				
Sn 123					Pu 239				
Sn 126					Pu 240				
Sb 125					Pu 241				
Sb 126					Pu 242				
Te 125m					Am 241				
Te 127m					Am 242m				
I 129					Am 243				
Cs 134					Cm 242				
Cs 135					Cm 243				
Cs 137					Cm 244				
Ba 133					Cm 245				
La 137					Cm 246				
La 138					Cm 248				
Ce 144					Cf 249				
Pm 145					Cf 250				
Pm 147					Cf 251				
Sm 147					Cf 252				
Sm 151					Other a		8		8
Eu 152		6		6	Other b/g		7		7
Eu 154		6		6	Total a	<1E-09	8	<1E-09	8
Eu 155		6		6	Total b/g	1.48E+01	DD 2	2.04E+01	DD 2

Bands (Upper and Lower)

- A a factor of 1.5
- B a factor of 3
- C a factor of 10
- D a factor of 100
- E a factor of 1000

Note: Bands quantify uncertainty in mean radioactivity.

Code

- 1 Measured activity
- 2 Derived activity (best estimate)
- 3 Derived activity (upper limit)
- 4 Not present
- 5 Present but not significant
- 6 Likely to be present but not assessed
- 7 Present in significant quantities but not determined
- 8 Not expected to be present in significant quantity