

WASTE STREAM	3K01	Pond Water Ion Exchange Material
---------------------	-------------	---

SITE Hartlepool

SITE OWNER EDFE NGL

WASTE CUSTODIAN EDFE NGL

WASTE TYPE ILW; SPD1

WASTE VOLUMES

		Reported
Stocks:	At 1.4.2019.....	11.4 m ³
Future arisings -	1.4.2019 - 31.3.2024.....	1.0 m ³
	1.4.2024 - 31.3.2027.....	1.2 m ³
Total future arisings:		2.2 m ³
Total waste volume:		13.6 m ³

Comment on volumes: Discharges of ion exchange resins are dependant on station operational requirements.

Uncertainty factors on volumes: Stock (upper): x 1.5 Arisings (upper) x 1.5
 Stock (lower): x 0.5 Arisings (lower) x 0.5

WASTE SOURCE Spent ion exchange materials.

PHYSICAL CHARACTERISTICS

General description: The waste is expected to be Purolite ion exchange material type NRW37(H/OH) (mixed bed resin). Also sludge associated with the ion exchange material. Some filter sand may also be accumulated with the ion exchange material. The ion exchange material is stored under water in tanks and should be easily pumped and have rapid settling characteristics. There are no large items which may require special handling.

Physical components (%vol): Ion exchange material, water, sludge, sand. Volume breakdown not assessed.

Sealed sources: The waste does not contain sealed sources.

Bulk density (t/m³): 1.1

Comment on density: -

CHEMICAL COMPOSITION

General description and components (%wt): Composition appropriate to proprietary ion exchange materials, most of which will be organic in nature. There may also be some sludge and sand.

Chemical state: -

Chemical form of radionuclides: -

Metals and alloys (%wt): -

Stainless steel.....	NE
Other ferrous metals.....	NE
Iron.....	NE
Aluminium.....	NE
Beryllium.....	NE
Cobalt.....	NE
Copper.....	NE
Lead.....	NE
Magnox/Magnesium.....	NE
Nickel.....	NE
Titanium.....	NE
Uranium.....	NE
Zinc.....	NE
Zircaloy/Zirconium.....	NE

WASTE STREAM**3K01****Pond Water Ion Exchange Material**

	Other metals.....	NE
Organics (%wt):	Proprietary organic ion-exchange resins will be present.	
	Total cellulose.....	0
	Paper, cotton.....	0
	Wood.....	0
	Halogenated plastics	0
	Total non-halogenated plastics.....	0
	Condensation polymers.....	0
	Others.....	0
	Organic ion exchange materials....	P
	Total rubber.....	0
	Halogenated rubber	0
	Non-halogenated rubber.....	0
	Hydrocarbons.....	0
	Oil or grease	
	Fuel.....	
	Asphalt/Tarmac (cont.coal tar)...	
	Asphalt/Tarmac (no coal tar).....	
	Bitumen.....	
	Others.....	
	Other organics.....	NE
Other materials (%wt):	-	
	Inorganic ion exchange materials.	NE
	Inorganic sludges and flocs.....	NE
	Soil.....	0
	Brick/Stone/Rubble.....	0
	Cementitious material.....	0
	Sand.....	P
	Glass/Ceramics.....	0
	Graphite.....	0
	Desiccants/Catalysts.....	0
	Asbestos.....	0
	Non/low friable.....	
	Moderately friable.....	
	Highly friable.....	
	Free aqueous liquids.....	P
	Free non-aqueous liquids.....	NE
	Powder/Ash.....	0
Inorganic anions (%wt):	Not assessed.	

WASTE STREAM

3K01

Pond Water Ion Exchange Material

Fluoride.....	NE
Chloride.....	NE
Iodide.....	NE
Cyanide.....	0
Carbonate.....	NE
Nitrate.....	NE
Nitrite.....	NE
Phosphate.....	NE
Sulphate.....	NE
Sulphide.....	NE

Materials of interest for waste acceptance criteria:

Ion exchange resins may be combustible when dry.

Combustible metals.....	0
Low flash point liquids.....	0
Explosive materials.....	0
Phosphorus.....	0
Hydrides.....	0
Biological etc. materials.....	0
Biodegradable materials.....	0
Putrescible wastes.....	0
Non-putrescible wastes.....	0
Corrosive materials.....	0
Pyrophoric materials.....	0
Generating toxic gases.....	0
Reacting with water.....	0
Active particles.....	P
Soluble solids as bulk chemical compounds.....	0

May be present

Hazardous substances / non hazardous pollutants:

-	
Acrylamide.....	NE
Benzene.....	NE
Chlorinated solvents.....	NE
Formaldehyde.....	NE
Organometallics.....	NE
Phenol.....	NE
Styrene.....	NE
Tri-butyl phosphate.....	NE
Other organophosphates.....	NE
Vinyl chloride.....	NE
Arsenic.....	NE
Barium.....	NE
Boron.....	NE

WASTE STREAM**3K01****Pond Water Ion Exchange Material**

Cadmium..... NE
 Caesium..... NE
 Selenium..... NE
 Chromium..... NE
 Molybdenum..... NE
 Thallium..... NE
 Tin..... NE
 Vanadium..... NE
 Mercury compounds..... NE
 Others..... NE
 Electronic Electrical Equipment (EEE)
 EEE Type 1..... 0
 EEE Type 2..... 0
 EEE Type 3..... 0
 EEE Type 4..... 0
 EEE Type 5..... 0

Complexing agents (%wt):

Not yet determined

EDTA..... NE
 DPTA..... NE
 NTA..... NE
 Polycarboxylic acids..... NE
 Other organic complexants..... NE
 Total complexing agents..... NE

Possibly in trace quantities.

PACKAGING AND CONDITIONING

Conditioning method: The waste is expected to be encapsulated in a BFS/OPC matrix. The fallback option is wet oxidation followed by encapsulation of the residual sludge (or possibly drying and supercompaction. Drums of supercompacted waste would be grouted in an "enhanced" drum). Other process options are being kept under review.

Plant Name: None.

Location: Hartlepool Power Station.

Plant startup date: Probably between 2029 and 2034.

Total capacity (m³/y incoming waste): ~175.0

Target start date for packaging this stream: -

Throughput for this stream (m³/y incoming waste): ~

Other information: All waste in a tank will be retrieved when a conditioning campaign is undertaken. There may be more than one campaign.

Likely container type:	Container	Waste packaged (%vol)	Waste loading (m ³)	Payload (m ³)	Number of packages
	500 l drum	100.0	~0.2	0.47	68

WASTE STREAM**3K01****Pond Water Ion Exchange Material**

Likely container type comment: -

Range in container waste volume: -

Other information on containers: The container material is expected to be stainless steel.

Likely conditioning matrix: BFS/OPC
Other information: A 9:1 BFS/OPC matrix is expected to be used.

Conditioned density (t/m³): ~1.7
Conditioned density comment: Density may vary from 1.62 - 1.72 t/m³.

Other information on conditioning: Appropriate plant to be provided at the Station in accordance with EDF Energy strategy.

Opportunities for alternative disposal routing: No

Treatment	Stream volume (%)	Comment
-	-	-

RADIOACTIVITY

Source: Contamination by activation products will be the main source of activity.

Uncertainty: Specific activity is a function of station operating history. The values quoted are indicative of those that might be expected after several years of operation.

Definition of total alpha and total beta/gamma: Where totals are shown on the table of radionuclide activities they are the sums of the listed alpha or beta/gamma emitting radionuclides plus 'other alpha' or 'other beta/gamma'.

Measurement of radioactivities: Theoretical estimates and some limited radiochemical analysis.

Other information: -

WASTE STREAM 3K01 Pond Water Ion Exchange Material

Nuclide	Mean radioactivity, TBq/m ³				Nuclide	Mean radioactivity, TBq/m ³			
	Waste at 1.4.2019	Bands and Code	Future arisings	Bands and Code		Waste at 1.4.2019	Bands and Code	Future arisings	Bands and Code
H 3	<2E-05	D 3	2E-05	C D 2	Gd 153				
Be 10		8		8	Ho 163				
C 14		8		8	Ho 166m				
Na 22		4		4	Tm 170				
Al 26		4		4	Tm 171				
Cl 36		6		6	Lu 174				
Ar 39					Lu 176				
Ar 42					Hf 178n				
K 40					Hf 182				
Ca 41		8		8	Pt 193				
Mn 53					Tl 204				
Mn 54	1E-02	C D 2	2E-01	C D 2	Pb 205				
Fe 55	6E-02	C D 2	3E-01	C D 2	Pb 210	8			8
Co 60	3E-01	C D 2	7E-01	C D 2	Bi 208				
Ni 59		6		6	Bi 210m				
Ni 63	8E-02	C D 2	8E-02	C D 2	Po 210	8			8
Zn 65	5E-04	C D 2	9E-03	C D 2	Ra 223				
Se 79		8		8	Ra 225				
Kr 81					Ra 226	8			8
Kr 85					Ra 228				
Rb 87					Ac 227				
Sr 90		8		8	Th 227				
Zr 93		8		8	Th 228				
Nb 91					Th 229	8			8
Nb 92					Th 230	8			8
Nb 93m		8		8	Th 232	8			8
Nb 94		8		8	Th 234	8			8
Mo 93		8		8	Pa 231	8			8
Tc 97					Pa 233				
Tc 99		8		8	U 232				
Ru 106	3E-05	C D 2	3E-04	C D 2	U 233	8			8
Pd 107		8		8	U 234	8			8
Ag 108m		8		8	U 235	8			8
Ag 110m	1E-04	C D 2	2E-03	C D 2	U 236	8			8
Cd 109					U 238	8			8
Cd 113m					Np 237	8			8
Sn 119m					Pu 236				
Sn 121m		8		8	Pu 238	8			8
Sn 123					Pu 239	8			8
Sn 126		8		8	Pu 240	8			8
Sb 125					Pu 241	8			8
Sb 126					Pu 242	8			8
Te 125m					Am 241	8			8
Te 127m					Am 242m	8			8
I 129		8		8	Am 243	8			8
Cs 134		8		8	Cm 242	8			8
Cs 135		8		8	Cm 243	8			8
Cs 137		8		8	Cm 244	8			8
Ba 133	6E-04	C D 2	1E-03	C D 2	Cm 245	8			8
La 137					Cm 246	8			8
La 138					Cm 248				
Ce 144	<2E-05	D 3	3E-04	C D 2	Cf 249				
Pm 145					Cf 250				
Pm 147		8		8	Cf 251				
Sm 147					Cf 252				
Sm 151		8		8	Other a	8			8
Eu 152		6		6	Other b/g	2E-02	C D 2	9E-01	C C 2
Eu 154	5E-04	C D 2	1E-03	C D 2	Total a	<1E-09	8	<1E-09	8
Eu 155	3E-04	C D 2	9E-04	C D 2	Total b/g	4.72E-01	C D 2	2.20E+00	C D 2

Bands (Upper and Lower)

- A a factor of 1.5
- B a factor of 3
- C a factor of 10
- D a factor of 100
- E a factor of 1000

Note: Bands quantify uncertainty in mean radioactivity.

Code

- 1 Measured activity
- 2 Derived activity (best estimate)
- 3 Derived activity (upper limit)
- 4 Not present
- 5 Present but not significant
- 6 Likely to be present but not assessed
- 7 Present in significant quantities but not determined
- 8 Not expected to be present in significant quantity