

WASTE STREAM	4C19	Pond Water Filtration Sludge
---------------------	-------------	-------------------------------------

SITE Torness

SITE OWNER EDFE NGL

WASTE CUSTODIAN EDFE NGL

WASTE TYPE ILW; SPD1

WASTE VOLUMES

		Reported
Stocks:	At 1.4.2019.....	1.8 m ³
Future arisings -	1.4.2019 - 31.3.2030.....	0.6 m ³
	1.4.2030 - 31.3.2032.....	0.2 m ³
Total future arisings:		0.8 m ³
Total waste volume:		2.5 m ³

Comment on volumes: Waste volumes will be variable depending on station operating conditions.

Uncertainty factors on volumes: Stock (upper): x 1.25 Arisings (upper) x 1.5
 Stock (lower): x 0.75 Arisings (lower) x 0.5

WASTE SOURCE Sludge and filter pre-coat material.

PHYSICAL CHARACTERISTICS

General description: Sludge and any filter precoat material. There are no large items that may require special handling.

Physical components (%wt): Filter Precoat containing pond debris. No other constituents identified.

Sealed sources: The waste does not contain sealed sources.

Bulk density (t/m³): ~1

Comment on density: -

CHEMICAL COMPOSITION

General description and components (%wt): Predominantly Filter precoat which is essentially mineral silica (silicon dioxide). There will also be debris filtered from pond water. Other materials not assessed.

Chemical state: Neutral

Chemical form of radionuclides: H-3: Contamination by tritiated water
 C-14: Contamination by activated graphite
 Cl-36: To Be determined
 Se-79: To Be determined
 Tc-99: To Be determined
 I-129: To Be determined
 Ra: To Be determined
 Th: To Be determined
 U: To Be determined
 Np: To Be determined
 Pu: To Be determined

Metals and alloys (%wt): -

Stainless steel.....	NE
Other ferrous metals.....	NE
Iron.....	NE
Aluminium.....	NE
Beryllium.....	NE
Cobalt.....	NE
Copper.....	NE
Lead.....	NE
Magnox/Magnesium.....	NE
Nickel.....	NE

WASTE STREAM**4C19****Pond Water Filtration Sludge**

	Titanium.....	NE
	Uranium.....	NE
	Zinc.....	NE
	Zircaloy/Zirconium.....	NE
	Other metals.....	NE
Organics (%wt):	To be further assessed following operational experience.	
	Total cellulose.....	0
	Paper, cotton.....	0
	Wood.....	0
	Halogenated plastics	0
	Total non-halogenated plastics.....	0
	Condensation polymers.....	0
	Others.....	0
	Organic ion exchange materials....	0
	Total rubber.....	0
	Halogenated rubber	0
	Non-halogenated rubber.....	0
	Hydrocarbons.....	0
	Oil or grease	
	Fuel.....	
	Asphalt/Tarmac (cont.coal tar)...	
	Asphalt/Tarmac (no coal tar)....	
	Bitumen.....	
	Others.....	
	Other organics.....	NE
Other materials (%wt):	-	
	Inorganic ion exchange materials.	0
	Inorganic sludges and flocs.....	100.0
	Soil.....	0
	Brick/Stone/Rubble.....	0
	Cementitious material.....	0
	Sand.....	0
	Glass/Ceramics.....	
	Graphite.....	0
	Desiccants/Catalysts.....	0
	Asbestos.....	0
	Non/low friable.....	
	Moderately friable.....	
	Highly friable.....	
	Free aqueous liquids.....	P
	Free non-aqueous liquids.....	P
	Powder/Ash.....	0
Inorganic anions (%wt):	Not assessed.	

WASTE STREAM

4C19

Pond Water Filtration Sludge

Fluoride.....	NE
Chloride.....	NE
Iodide.....	NE
Cyanide.....	NE
Carbonate.....	NE
Nitrate.....	NE
Nitrite.....	NE
Phosphate.....	NE
Sulphate.....	NE
Sulphide.....	NE

Materials of interest for waste acceptance criteria:

No material likely to represent a fire or other non-radiological hazard is expected to be present.

Combustible metals.....	0
Low flash point liquids.....	0
Explosive materials.....	0
Phosphorus.....	0
Hydrides.....	0
Biological etc. materials.....	0
Biodegradable materials.....	0
Putrescible wastes.....	0
Non-putrescible wastes.....	0
Corrosive materials.....	0
Pyrophoric materials.....	0
Generating toxic gases.....	0
Reacting with water.....	0
Active particles.....	P
Soluble solids as bulk chemical compounds.....	0

May be present

Hazardous substances / non hazardous pollutants:

-	
Acrylamide.....	NE
Benzene.....	NE
Chlorinated solvents.....	NE
Formaldehyde.....	NE
Organometallics.....	NE
Phenol.....	NE
Styrene.....	NE
Tri-butyl phosphate.....	NE
Other organophosphates.....	NE
Vinyl chloride.....	NE
Arsenic.....	NE
Barium.....	NE
Boron.....	NE

WASTE STREAM	4C19	Pond Water Filtration Sludge
---------------------	-------------	-------------------------------------

Cadmium..... NE
 Caesium..... NE
 Selenium..... NE
 Chromium..... NE
 Molybdenum..... NE
 Thallium..... NE
 Tin..... NE
 Vanadium..... NE
 Mercury compounds..... NE
 Others..... NE
 Electronic Electrical Equipment (EEE)
 EEE Type 1..... 0
 EEE Type 2..... 0
 EEE Type 3..... 0
 EEE Type 4..... 0
 EEE Type 5..... 0

Complexing agents (%wt): Not yet determined
 EDTA..... NE
 DPTA..... NE
 NTA..... NE
 Polycarboxylic acids..... NE
 Other organic complexants..... NE
 Total complexing agents..... NE

Expect only trace quantities, if any.

PACKAGING AND CONDITIONING

Conditioning method: The waste is expected to be encapsulated in a BFS/OPC matrix. Another approach being kept under review is (i) to dry the sludge (ii) to supercompact drums of dry sludge (iii) to grout the supercompacted drums in an "enhanced" drum.
 Plant Name: None.
 Location: Torness Power Station.
 Plant startup date: Expected between 2035 and 2038.
 Total capacity (m³/y incoming waste): ~175.0
 Target start date for packaging this stream: -
 Throughput for this stream (m³/y incoming waste): -
 Other information: All waste will be retrieved when a conditioning campaign is undertaken. It is expected that there will be several campaigns.

Likely container type:	Container	Waste packaged (%vol)	Waste loading (m ³)	Payload (m ³)	Number of packages
	500 l drum	~100.0	~0.33	~0.47	8

WASTE STREAM	4C19	Pond Water Filtration Sludge
---------------------	-------------	-------------------------------------

Likely container type comment: -

Range in container waste volume: -

Other information on containers: Stainless Steel

Likely conditioning matrix: BFS/OPC
 Other information: A 9:1 BFS/OPC matrix to formula FS044A is expected.

Conditioned density (t/m³): ~1.76
 Conditioned density comment: Density in the range 1.68 - 1.84 t/m³ is expected.

Other information on conditioning: -

Opportunities for alternative disposal routing: No

Treatment	Stream volume (%)	Comment
-	-	-

RADIOACTIVITY

Source: Contaminated filter precoat. Contamination by activation products will be the main source of activity.

Uncertainty: Requires further assessment.

Definition of total alpha and total beta/gamma: Where totals are shown on the table of radionuclide activities they are the sums of the listed alpha or beta/gamma emitting radionuclides plus 'other alpha' or 'other beta/gamma'.

Measurement of radioactivities: Not yet assessed.

Other information: -

WASTE STREAM 4C19 Pond Water Filtration Sludge

Nuclide	Mean radioactivity, TBq/m ³				Nuclide	Mean radioactivity, TBq/m ³			
	Waste at 1.4.2019	Bands and Code	Future arisings	Bands and Code		Waste at 1.4.2019	Bands and Code	Future arisings	Bands and Code
H 3		6		6	Gd 153				
Be 10		8		8	Ho 163				
C 14		8		8	Ho 166m				
Na 22		4		4	Tm 170				
Al 26		4		4	Tm 171				
Cl 36		6		6	Lu 174				
Ar 39					Lu 176				
Ar 42					Hf 178n				
K 40					Hf 182				
Ca 41		8		8	Pt 193				
Mn 53					Tl 204				
Mn 54	6.33E-03	CC 2	1.06E-01	DD 2	Pb 205				
Fe 55	2E+00	CC 2	1.64E+01	DD 2	Pb 210		8		8
Co 60	2.52E-02	CC 2	9.5E-02	DD 2	Bi 208				
Ni 59		6		6	Bi 210m				
Ni 63		6		6	Po 210		8		8
Zn 65	1E-02	CC 2	1.95E-01	DD 2	Ra 223				
Se 79		6		6	Ra 225				
Kr 81					Ra 226		8		8
Kr 85					Ra 228				
Rb 87					Ac 227				
Sr 90		6		6	Th 227				
Zr 93		6		6	Th 228				
Nb 91					Th 229		8		8
Nb 92					Th 230		8		8
Nb 93m		8		8	Th 232		8		8
Nb 94		6		6	Th 234				
Mo 93		8		8	Pa 231		8		8
Tc 97					Pa 233				
Tc 99		6		6	U 232				
Ru 106	<1E-02	C 3	<1.48E-01	D 3	U 233		8		8
Pd 107		8		8	U 234		6		6
Ag 108m	<2E-05	C 3	<2E-05	D 3	U 235		6		6
Ag 110m	2.08E-04	CC 2	3.95E-03	DD 2	U 236		6		6
Cd 109					U 238		6		6
Cd 113m					Np 237		6		6
Sn 119m					Pu 236				
Sn 121m		8		8	Pu 238	2E-04	CC 2	2.24E-04	DD 2
Sn 123					Pu 239	2E-04	CC 2	2E-04	DD 2
Sn 126		6		6	Pu 240	4E-04	CC 2	4E-04	DD 2
Sb 125	<9E-06	C 3	<5.92E-05	D 3	Pu 241	4E-02	CC 2	7.4E-02	DD 2
Sb 126					Pu 242		6		6
Te 125m					Am 241	1.64E-03	CC 2	1.64E-03	DD 2
Te 127m					Am 242m		6		6
I 129		6		6	Am 243		6		6
Cs 134	2.2E-04	CC 2	1.89E-03	DD 2	Cm 242	1E-05	CC 2	2.36E-04	DD 2
Cs 135		6		6	Cm 243	1E-06	CC 2	1.38E-06	DD 2
Cs 137	4.79E-03	CC 2	6.56E-03	DD 2	Cm 244	4E-05	CC 2	6.6E-05	DD 2
Ba 133					Cm 245		8		8
La 137					Cm 246		8		8
La 138					Cm 248				
Ce 144	<3E-03	C 3	<5.30E-02	D 3	Cf 249				
Pm 145					Cf 250				
Pm 147		6		6	Cf 251				
Sm 147					Cf 252				
Sm 151		6		6	Other a	<1E-09	8	<1E-09	8
Eu 152	<3E-05	C 3	<5.73E-05	D 2	Other b/g	1E-03	CC 2	1E-03	DD 2
Eu 154	5.43E-04	CC 2	1.39E-03	DD 2	Total a	2.49E-03	CC 2	2.77E-03	DD 2
Eu 155	3.18E-04	CC 2	1.30E-03	DD 2	Total b/g	2.07E+00	CC 2	1.71E+01	DD 2

Bands (Upper and Lower)

- A a factor of 1.5
- B a factor of 3
- C a factor of 10
- D a factor of 100
- E a factor of 1000

Note: Bands quantify uncertainty in mean radioactivity.

Code

- 1 Measured activity
- 2 Derived activity (best estimate)
- 3 Derived activity (upper limit)
- 4 Not present
- 5 Present but not significant
- 6 Likely to be present but not assessed
- 7 Present in significant quantities but not determined
- 8 Not expected to be present in significant quantity