

WASTE STREAM**9A46****Miscellaneous Activated Components****SITE** Berkeley**SITE OWNER** Nuclear Decommissioning Authority**WASTE CUSTODIAN** Magnox Limited**WASTE TYPE** ILW; SPD3**WASTE VOLUMES**Stocks: At 1.4.2019..... Reported ~10.0 m³Total future arisings: 0 m³Total waste volume: 10.0 m³

Comment on volumes: These components are not expected to arise during Care and Maintenance Preparation. This waste is assumed to be retained to Final Dismantling. Station operation ceased in March 1989.

Uncertainty factors on volumes: Stock (upper): x 1.2 Arisings (upper) x
Stock (lower): x 0.8 Arisings (lower) x**WASTE SOURCE** Irradiated components removed from the reactors.**PHYSICAL CHARACTERISTICS**

General description: Redundant or defective components such as control rods and chutes removed from reactor cores. Control rods are 8.5 m long x 50 mm diameter and weigh about 80 kg. Other items weigh about 1 to 1.5 t per item.

Physical components (%vol): Control rods, chutes, periscope and shield plug. Volume breakdown not assessed.

Sealed sources: -

Bulk density (t/m³): ~1Comment on density: The bulk density of the waste ranges in value up to 7.5 t/m³. The minimum value has not been assessed. The average is probably about 1 t/m³.**CHEMICAL COMPOSITION**

General description and components (%wt): The waste is principally steel components. Steel (~90%).

Chemical state: Neutral

Chemical form of radionuclides: H-3: Tritium may be incorporated in the waste or present as surface contamination in the form of inorganic or organic compounds.

C-14: Chemical form of carbon 14 has not been determined but may be graphite.

Cl-36: The chemical form of chlorine 36 has not been determined.

U: Chemical form of uranium isotopes has not been determined but may be uranium oxides.

Pu: Chemical form of plutonium isotopes has not been determined but may be plutonium oxides.

Metals and alloys (%wt): Nearly all of the waste is bulk metal. Dimensions have not been assessed.

Stainless steel..... NE

Other ferrous metals..... ~90.0 Carbon steels and boron steels are present.

Iron.....

Aluminium..... NE

Beryllium..... TR

Cobalt.....

Copper..... NE

Lead..... NE

Magnox/Magnesium..... NE

Nickel.....

Titanium.....

WASTE STREAM

9A46

Miscellaneous Activated Components

	Uranium.....		
	Zinc.....	NE	
	Zircaloy/Zirconium.....	NE	
	Other metals.....	NE	The presence of "other" metals has not been assessed.
Organics (%wt):	There may be small quantities (<1 wt%) of organic material present but none has been identified.		
	Total cellulose.....	0	
	Paper, cotton.....	0	
	Wood.....	0	
	Halogenated plastics	0	
	Total non-halogenated plastics.....	0	
	Condensation polymers.....	0	
	Others.....	0	
	Organic ion exchange materials....	0	
	Total rubber.....	0	
	Halogenated rubber	0	
	Non-halogenated rubber.....	0	
	Hydrocarbons.....		
	Oil or grease		
	Fuel.....		
	Asphalt/Tarmac (cont.coal tar)...		
	Asphalt/Tarmac (no coal tar)....		
	Bitumen.....		
	Others.....		
	Other organics.....	<1.0	
Other materials (%wt):	Graphite contamination.		
	Inorganic ion exchange materials.	0	
	Inorganic sludges and flocs.....	0	
	Soil.....	0	
	Brick/Stone/Rubble.....	0	
	Cementitious material.....	<10.0	
	Sand.....		
	Glass/Ceramics.....	NE	
	Graphite.....	TR	
	Desiccants/Catalysts.....		
	Asbestos.....	0	
	Non/low friable.....		
	Moderately friable.....		
	Highly friable.....		
	Free aqueous liquids.....	0	
	Free non-aqueous liquids.....	TR	
	Powder/Ash.....	0	

WASTE STREAM**9A46****Miscellaneous Activated Components**

Inorganic anions (%wt):

Inorganic anions are not expected to be present in more than trace quantities.

Fluoride.....	TR
Chloride.....	TR
Iodide.....	TR
Cyanide.....	0
Carbonate.....	TR
Nitrate.....	TR
Nitrite.....	TR
Phosphate.....	TR
Sulphate.....	TR
Sulphide.....	TR

Materials of interest for waste acceptance criteria:

There are no identified materials likely to represent a fire or other non-radiological hazard.

Combustible metals.....	0
Low flash point liquids.....	0
Explosive materials.....	0
Phosphorus.....	0
Hydrides.....	0
Biological etc. materials.....	0
Biodegradable materials.....	
Putrescible wastes.....	0
Non-putrescible wastes.....	
Corrosive materials.....	0
Pyrophoric materials.....	0
Generating toxic gases.....	0
Reacting with water.....	0
Active particles.....	
Soluble solids as bulk chemical compounds.....	

Hazardous substances / non hazardous pollutants:

-
Acrylamide.....
Benzene.....
Chlorinated solvents.....
Formaldehyde.....
Organometallics.....
Phenol.....
Styrene.....
Tri-butyl phosphate.....
Other organophosphates.....
Vinyl chloride.....
Arsenic.....
Barium.....

WASTE STREAM**9A46****Miscellaneous Activated Components**

Boron.....
 Cadmium.....
 Caesium.....
 Selenium.....
 Chromium.....
 Molybdenum.....
 Thallium.....
 Tin.....
 Vanadium.....
 Mercury compounds.....
 Others.....
 Electronic Electrical Equipment (EEE)
 EEE Type 1.....
 EEE Type 2.....
 EEE Type 3.....
 EEE Type 4.....
 EEE Type 5.....

Complexing agents (%wt): No
 EDTA.....
 DPTA.....
 NTA.....
 Polycarboxylic acids.....
 Other organic complexants.....
 Total complexing agents..... 0

PACKAGING AND CONDITIONING

Conditioning method: The waste is not expected to be supercompacted. The treatment envisaged is the placement of the waste in baskets followed by encapsulation of the baskets in the container.

Plant Name: None

Location: Berkeley Site

Plant startup date: 2074

Total capacity (m³/y incoming waste): ~5000.0

Target start date for packaging this stream: 2074

Throughput for this stream (m³/y incoming waste): ~2.0

Other information: Reactor demolition is assumed to start 3 years after the beginning of final decommissioning. The current proposal is to store the waste as at present until reactor dismantling. All waste is expected to be retrieved and conditioned when the conditioning campaign is undertaken.

Likely container type:	Container	Waste packaged (%vol)	Waste loading (m ³)	Payload (m ³)	Number of packages
	4m box (no shielding)	100.0	16.2	18.9	< 1

WASTE STREAM**9A46****Miscellaneous Activated Components**

Likely container type comment: The waste is assumed to be in baskets in the waste package so the occupied volume in the package is greater than the original waste volume. Container choice may be influenced by Transport Regulations at the time of Final Site Clearance.

Range in container waste volume: Not yet determined.

Other information on containers: The container material is expected to be stainless steel.

Likely conditioning matrix: Blast Furnace Slag / Ordinary Portland Cement

Other information: The waste is assumed to be encapsulated.

Conditioned density (t/m³): ~3.0

Conditioned density comment: The conditioned waste density assumes that the waste will be encapsulated.

Other information on conditioning: The waste will be in baskets placed in the waste packages. Baskets of different ILW wastes may be in the same waste packages. The encapsulation matrix would be likely to be BFS/OPC. The density of the encapsulated waste would probably be about 3 t/m³.

Opportunities for alternative disposal routing: No

Treatment	Stream volume (%)	Comment
-	-	-

RADIOACTIVITY

Source: Irradiated components removed from the reactor. Control rods are likely to be components of high activity.

Uncertainty: Specific activity is a function of Station operating history. The values quoted are indicative of the activities that might be expected.

Definition of total alpha and total beta/gamma: Where totals are shown on the table of radionuclide activities they are the sums of the listed alpha or beta/gamma emitting radionuclides plus 'other alpha' or 'other beta/gamma'.

Measurement of radioactivities: Estimates are based upon theoretical assessments.

Other information: -

WASTE STREAM

9A46

Miscellaneous Activated Components

Nuclide	Mean radioactivity, TBq/m ³				Nuclide	Mean radioactivity, TBq/m ³			
	Waste at 1.4.2019	Bands and Code	Future arisings	Bands and Code		Waste at 1.4.2019	Bands and Code	Future arisings	Bands and Code
H 3	<1.02E+00	D 3			Gd 153		8		
Be 10		8			Ho 163		8		
C 14	2.00E-02	CD 2			Ho 166m		8		
Na 22		8			Tm 170		8		
Al 26		8			Tm 171		8		
Cl 36	3E-05	CC 2			Lu 174		8		
Ar 39		8			Lu 176		8		
Ar 42		8			Hf 178n		8		
K 40		8			Hf 182		8		
Ca 41		8			Pt 193		8		
Mn 53		8			Tl 204		8		
Mn 54		8			Pb 205		8		
Fe 55	1.87E-02	CD 2			Pb 210		8		
Co 60	2.06E-01	CD 2			Bi 208		8		
Ni 59	4E-02	CD 2			Bi 210m		8		
Ni 63	2.76E+00	CD 2			Po 210		8		
Zn 65		8			Ra 223		8		
Se 79		8			Ra 225		8		
Kr 81		8			Ra 226		8		
Kr 85		8			Ra 228		8		
Rb 87		8			Ac 227		8		
Sr 90	<3.00E-05	D 3			Th 227		8		
Zr 93		8			Th 228		8		
Nb 91		8			Th 229		8		
Nb 92		8			Th 230		8		
Nb 93m		8			Th 232		8		
Nb 94	4E-05	CD 2			Th 234	<7E-09	D 3		
Mo 93		8			Pa 231		8		
Tc 97		8			Pa 233		8		
Tc 99	<1E-08	D 3			U 232		8		
Ru 106		8			U 233		8		
Pd 107		8			U 234	<6.08E-09	D 3		
Ag 108m	3.92E-05	CD 2			U 235		8		
Ag 110m		8			U 236		8		
Cd 109		8			U 238	<7E-09	D 3		
Cd 113m		8			Np 237		8		
Sn 119m		8			Pu 236		8		
Sn 121m		8			Pu 238	<1.82E-06	D 3		
Sn 123		8			Pu 239	<3E-06	D 3		
Sn 126		8			Pu 240	<4.00E-06	D 3		
Sb 125		8			Pu 241	<3.37E-05	D 3		
Sb 126		8			Pu 242	<2E-09	D 3		
Te 125m		8			Am 241	<9.70E-06	D 3		
Te 127m		8			Am 242m	<1.88E-08	D 3		
I 129		8			Am 243	<6.00E-09	D 3		
Cs 134		8			Cm 242	<1.55E-08	D 3		
Cs 135		8			Cm 243	<3.03E-09	D 3		
Cs 137	<5.30E-05	D 3			Cm 244	<3.17E-08	D 3		
Ba 133		8			Cm 245		8		
La 137		8			Cm 246		8		
La 138		8			Cm 248		8		
Ce 144		8			Cf 249		8		
Pm 145		8			Cf 250		8		
Pm 147		8			Cf 251		8		
Sm 147		8			Cf 252		8		
Sm 151	<7.29E-07	D 3			Other a				
Eu 152	3.76E-06	CD 2			Other b/g				
Eu 154	1.91E-06	CD 2			Total a	1.86E-05	CD 2	0	
Eu 155		8			Total b/g	4.07E+00	CD 2	0	

Bands (Upper and Lower)

- A a factor of 1.5
- B a factor of 3
- C a factor of 10
- D a factor of 100
- E a factor of 1000

Note: Bands quantify uncertainty in mean radioactivity.

Code

- 1 Measured activity
- 2 Derived activity (best estimate)
- 3 Derived activity (upper limit)
- 4 Not present
- 5 Present but not significant
- 6 Likely to be present but not assessed
- 7 Present in significant quantities but not determined
- 8 Not expected to be present in significant quantity