

<b>WASTE STREAM</b>	<b>9C314</b>	<b>Mild Steel (Reactor) LLW</b>
---------------------	--------------	---------------------------------

**SITE** Dungeness A  
**SITE OWNER** Nuclear Decommissioning Authority  
**WASTE CUSTODIAN** Magnox Limited  
**WASTE TYPE** LLW

**WASTE VOLUMES**

		Reported
Stocks:	At 1.4.2019.....	0 m <sup>3</sup>
Future arisings -	1.4.2092 - 31.3.2095.....	457.0 m <sup>3</sup>
Total future arisings:		457.0 m <sup>3</sup>
Total waste volume:		457.0 m <sup>3</sup>

Comment on volumes: For inventory purposes the arisings are assumed to arise at a uniform rate over three years. Final Dismantling & Site Clearance is assumed to commence in 2088 with reactor dismantling commencing in 2092 and lasting for 3 years. The volumes and radioactivity have been calculated for 85 years after reactor shutdown, i.e. 2091.

Uncertainty factors on volumes:  
 Stock (upper): x Arisings (upper) x 1.2  
 Stock (lower): x Arisings (lower) x 0.8

**WASTE SOURCE** Mild steel items from the reactor structure.

**PHYSICAL CHARACTERISTICS**

General description: A variety of mild steel items including the pressure vessel. Waste can be packaged in standard LLW containers.  
 Physical components (%wt): Mild steel items (100%).  
 Sealed sources: -  
 Bulk density (t/m<sup>3</sup>): ~1.4  
 Comment on density: The density is of the waste as cut for packaging.

**CHEMICAL COMPOSITION**

General description and components (%wt): Mild steel (100%).  
 Chemical state: Neutral  
 Chemical form of radionuclides:  
 H-3: The tritium content is insignificant.  
 C-14: The carbon 14 is incorporated in the steel. There also may be some contamination as graphite.  
 Cl-36: The chlorine 36 will be incorporated in the steel.  
 Se-79: The selenium content is insignificant.  
 Tc-99: The chemical form of technetium has not been determined.  
 Ra: The radium content is insignificant.  
 Th: The thorium content is insignificant.  
 U: The uranium content is insignificant.  
 Np: The neptunium content is insignificant.  
 Pu: The plutonium content is insignificant.

Metals and alloys (%wt): All of the waste will be bulk metal items which have been cut for packaging. Metal thicknesses will probably range from a few mm to about 100 mm.

Stainless steel.....	0	
Other ferrous metals.....	100.0	Mild steel types are BS150E-171, BS1501, BS15 and PV Steel (Coltuf 28).
Iron.....		
Aluminium.....	0	
Beryllium.....	0	
Cobalt.....	~0.01	Greatest measured value from the various components.
Copper.....	0	

**WASTE STREAM****9C314 Mild Steel (Reactor) LLW**

	Lead.....	0	
	Magnox/Magnesium.....	0	
	Nickel.....	<0.10	Greatest measured value from the various components.
	Titanium.....		
	Uranium.....		
	Zinc.....	0	
	Zircaloy/Zirconium.....	0	
	Other metals.....	TR	Silver and niobium.
Organics (%wt):	None expected. There are no halogenated plastics and rubbers present.		
	Total cellulose.....	0	
	Paper, cotton.....	0	
	Wood.....	0	
	Halogenated plastics .....	0	
	Total non-halogenated plastics.....	0	
	Condensation polymers.....	0	
	Others.....	0	
	Organic ion exchange materials....	0	
	Total rubber.....	0	
	Halogenated rubber .....	0	
	Non-halogenated rubber.....	0	
	Hydrocarbons.....		
	Oil or grease .....		
	Fuel.....		
	Asphalt/Tarmac (cont.coal tar)...		
	Asphalt/Tarmac (no coal tar)....		
	Bitumen.....		
	Others.....		
	Other organics.....	0	
Other materials (%wt):	Some graphite dust may be associated with reactor materials.		
	Inorganic ion exchange materials.	0	
	Inorganic sludges and flocs.....	0	
	Soil.....	0	
	Brick/Stone/Rubble.....	0	
	Cementitious material.....	0	
	Sand.....		
	Glass/Ceramics.....	0	
	Graphite.....	TR	
	Desiccants/Catalysts.....		
	Asbestos.....	0	
	Non/low friable.....		
	Moderately friable.....		
	Highly friable.....		

**WASTE STREAM****9C314 Mild Steel (Reactor) LLW**

	Free aqueous liquids.....	0
	Free non-aqueous liquids.....	0
	Powder/Ash.....	0
Inorganic anions (%wt):	There may be a trace of chloride present.	
	Fluoride.....	0
	Chloride.....	TR
	Iodide.....	0
	Cyanide.....	0
	Carbonate.....	0
	Nitrate.....	0
	Nitrite.....	0
	Phosphate.....	0
	Sulphate.....	0
	Sulphide.....	0
Materials of interest for waste acceptance criteria:	No materials likely to pose a fire or other non-radiological hazard have been identified.	
	Combustible metals.....	0
	Low flash point liquids.....	0
	Explosive materials.....	0
	Phosphorus.....	0
	Hydrides.....	0
	Biological etc. materials.....	0
	Biodegradable materials.....	
	Putrescible wastes.....	0
	Non-putrescible wastes.....	
	Corrosive materials.....	0
	Pyrophoric materials.....	0
	Generating toxic gases.....	0
	Reacting with water.....	0
	Active particles.....	
	Soluble solids as bulk chemical compounds.....	
Hazardous substances / non hazardous pollutants:	None expected.	
	Acrylamide.....	
	Benzene.....	
	Chlorinated solvents.....	
	Formaldehyde.....	
	Organometallics.....	
	Phenol.....	
	Styrene.....	
	Tri-butyl phosphate.....	
	Other organophosphates.....	

**WASTE STREAM****9C314 Mild Steel (Reactor) LLW**

Vinyl chloride.....  
 Arsenic.....  
 Barium.....  
 Boron.....  
 Cadmium.....  
 Caesium.....  
 Selenium.....  
 Chromium.....  
 Molybdenum.....  
 Thallium.....  
 Tin.....  
 Vanadium.....  
 Mercury compounds.....  
 Others.....  
 Electronic Electrical Equipment (EEE)  
     EEE Type 1.....  
     EEE Type 2.....  
     EEE Type 3.....  
     EEE Type 4.....  
     EEE Type 5.....

Complexing agents (%wt):

EDTA.....  
 DPTA.....  
 NTA.....  
 Polycarboxylic acids.....  
 Other organic complexants.....  
 Total complexing agents..... TR

**TREATMENT, PACKAGING AND DISPOSAL**

Planned on-site / off-site treatment(s):

Treatment	On-site / Off site	Stream volume %
Low force compaction		
Supercompaction (HFC)		
Incineration		
Solidification		
Decontamination		
Metal treatment		
Size reduction		
Decay storage		
Recycling / reuse		
Other / various		
None		100.0

Comment on planned treatments:

-

**WASTE STREAM****9C314****Mild Steel (Reactor) LLW****Disposal Routes:**

Disposal Route	Stream volume %
Expected to be consigned to the LLW Repository Expected to be consigned to a Landfill Facility Expected to be consigned to an On-Site Disposal Facility Expected to be consigned to an Incineration Facility Expected to be consigned to a Metal Treatment Facility Expected to be consigned as Out of Scope Expected to be recycled / reused Disposal route not known	100.0

**Upcoming (2019/20-2021/22) Waste Routing (if expected to change from above):**

Disposal Route	Stream volume %		
	2019/20	2020/21	2021/22
Expected to be consigned to the LLW Repository Expected to be consigned to a Landfill Facility Expected to be consigned to an On-Site Disposal Facility Expected to be consigned to an Incineration Facility Expected to be consigned to a Metal Treatment Facility Expected to be consigned as Out of Scope Expected to be recycled / reused Disposal route not known			

**Waste Packaging for Disposal:**

Container	Stream volume %	Waste loading m <sup>3</sup>	Number of packages
1/3 Height IP-1 ISO 2/3 Height IP-2 ISO 1/2 Height WAMAC IP-2 ISO 1/2 Height IP-2 Disposal/Re-usable ISO 2m box (no shielding) 4m box (no shielding) Other	100.0	10	46

## Other information:

Data have been presented as though the waste will be in dedicated containers. However it is likely that this waste will be placed in containers with other LLW.

**Waste Planned for Disposal at the LLW Repository:**

Container voidage: Inaccessible voidage is not expected.

Waste Characterisation Form (WCH): -

Waste consigned for disposal to LLWR in year of generation: The timing of consignment of the waste for disposal cannot be determined at present.

Potential for the waste to contain discrete items: -

**Non-Containerised Waste for In-Vault Grouting:** (Not applicable to this waste stream)

Stream volume (%): -

Waste stream variation: -

Bounding cuboidal volume:

Inaccessible voidage: -

Other information: -

**WASTE STREAM****9C314****Mild Steel (Reactor) LLW****RADIOACTIVITY**

Source:	Activation of the mild steel and its impurities.
Uncertainty:	The values quoted were derived by calculation from available material specifications and are indicative of the activities that are to be expected. The major source of uncertainty is the impurity levels.
Definition of total alpha and total beta/gamma:	Total beta/gamma is defined as the sum of the listed activities of all nuclides other than alpha emitters. All alpha emitter activities are insignificant.
Measurement of radioactivities:	The specific activities were estimated from neutron activation calculations of the material and its impurities.
Other information:	The activities quoted are those at 85 years after reactor shutdown, i.e. in 2091. There may be some contamination by Cs137.

**WASTE STREAM**

**9C314**

**Mild Steel (Reactor) LLW**

Nuclide	Mean radioactivity, TBq/m <sup>3</sup>				Nuclide	Mean radioactivity, TBq/m <sup>3</sup>			
	Waste at 1.4.2019	Bands and Code	Future arisings	Bands and Code		Waste at 1.4.2019	Bands and Code	Future arisings	Bands and Code
H 3				8	Gd 153				8
Be 10				8	Ho 163				8
C 14			1.23E-03	C C 2	Ho 166m				8
Na 22				8	Tm 170				8
Al 26				8	Tm 171				8
Cl 36			1.89E-07	C C 2	Lu 174				8
Ar 39				8	Lu 176				8
Ar 42				8	Hf 178n				8
K 40				8	Hf 182				8
Ca 41				8	Pt 193				8
Mn 53				8	Tl 204		3.09E-09	C C 2	8
Mn 54				8	Pb 205				8
Fe 55			5.59E-09	C C 2	Pb 210				8
Co 60			8.92E-06	C C 2	Bi 208				8
Ni 59			7.16E-05	C C 2	Bi 210m				8
Ni 63			4.04E-03	C C 2	Po 210				8
Zn 65				8	Ra 223				8
Se 79				8	Ra 225				8
Kr 81				8	Ra 226				8
Kr 85				8	Ra 228				8
Rb 87				8	Ac 227				8
Sr 90				8	Th 227				8
Zr 93				8	Th 228				8
Nb 91				8	Th 229				8
Nb 92				8	Th 230				8
Nb 93m				6	Th 232				8
Nb 94			8.57E-08	C C 2	Th 234				8
Mo 93			1.63E-05	C C 2	Pa 231				8
Tc 97				8	Pa 233				8
Tc 99			3.75E-06	C C 2	U 232				8
Ru 106				8	U 233				8
Pd 107				8	U 234				8
Ag 108m			9E-07	C C 2	U 235				8
Ag 110m				8	U 236				8
Cd 109				8	U 238				8
Cd 113m				8	Np 237				8
Sn 119m				8	Pu 236				8
Sn 121m				8	Pu 238				8
Sn 123				8	Pu 239				8
Sn 126				8	Pu 240				8
Sb 125				8	Pu 241				8
Sb 126				8	Pu 242				8
Te 125m				8	Am 241				8
Te 127m				8	Am 242m				8
I 129				8	Am 243				8
Cs 134				8	Cm 242				8
Cs 135				8	Cm 243				8
Cs 137				6	Cm 244				8
Ba 133				8	Cm 245				8
La 137				8	Cm 246				8
La 138				8	Cm 248				8
Ce 144				8	Cf 249				8
Pm 145				8	Cf 250				8
Pm 147				8	Cf 251				8
Sm 147				8	Cf 252				8
Sm 151				8	Other a				
Eu 152				8	Other b/g				
Eu 154				8	<b>Total a</b>	<b>0</b>	<b>0</b>		
Eu 155				8	<b>Total b/g</b>	<b>0</b>	<b>5.37E-03</b>	<b>C C 2</b>	

**Bands (Upper and Lower)**

- A a factor of 1.5
- B a factor of 3
- C a factor of 10
- D a factor of 100
- E a factor of 1000

Note: Bands quantify uncertainty in mean radioactivity.

**Code**

- 1 Measured activity
- 2 Derived activity (best estimate)
- 3 Derived activity (upper limit)
- 4 Not present
- 5 Present but not significant
- 6 Likely to be present but not assessed
- 7 Present in significant quantities but not determined
- 8 Not expected to be present in significant quantity