SITE Hinkley Point B

SITE OWNER EDFE NGL
WASTE CUSTODIAN EDFE NGL

WASTE TYPE LLW

Is the waste subject to Scottish Policy:

No

WASTE VOLUMES

WASIL VOLUMES		Reported	
Stocks:	At 1.4.2022	20.0 m ³	
Future arisings -	1.4.2022 - 31.3.2025 1.4.2025 - 31.3.2026 1.4.2026 - 31.3.2027 1.4.2027 - 31.3.2028 1.4.2028 - 31.3.2029 1.4.2029 - 31.3.2030 1.4.2030 - 31.3.2031	38.0 m ³ 46.0 m ³ 51.0 m ³ 103.0 m ³ 3.2 m ³ 6.3 m ³ 3.8 m ³	
Total future arisings: Total waste volume:		254.5 m ³ 274.5 m ³	

Comment on volumes: Waste volumes will be variable depending on station operating conditions.

Uncertainty factors on Stock (upper): x 1.25 Arisings (upper) x 1.5 volumes: X 0.75 Arisings (lower) x 0.5

WASTE SOURCE The wastes included in this stream are from the Ative Efluent Treatment Plant (AETP)

and Ponds areas. Solid waste arises mainly from maintenance and refurbishment work consisting of items which have been contaminated during operation. Additionally material arising from these areas may include disposable PPE, sampling material and cleaning

material.

PHYSICAL CHARACTERISTICS

General description: The wastes generated in these areas are mixed wastes ranging from metal items, spent

metal and paper candle filters, redundant plant items, general soft trash waste, heavy duty plastic and rubber waste. Free liquid: Removed as far as is practicable, and disposed via liquid effluent route. Conditioning of waste is not routinely required, however, sludge can

be conditioned if the sludge contains no additional hazardous materials.

Physical components (%wt): Metal (~55%), Plastics (halogenated) (~35%), Rubber (~4%), Wood (~5%), other organic

 $(\sim 1\%)$

Sealed sources: The waste does not contain sealed sources.

Bulk density (t/m³): ~0.46

Comment on density: Density based on raw volume and weight at arising as provided in WCH.

CHEMICAL COMPOSITION

General description and

components (%wt):

Iron (~55%), Plastics (halogenated) (~35%), Rubber (~4%), Wood (~5%), other organic

(~1%)

Chemical state: Neutral

Chemical form of

radionuclides: C-14: As graphite pariculate and incorporated into metal particles.

H-3: Diffused into materials

CI-36: Incorporated into steels
Se-79: Not expected to be significant
Tc-99: Not expected to be significant
I-129: Not expected to be significant
Ra: Not expected to be significant
Th: Not expected to be significant

U: Not Assessed

Np: Not expected to be significant

Pu: Not Assessed

Metals and alloys (%wt): Drum wall thickness will be about 1mm.

2022 Inventory

	(%wt)	Type(s) / Grade(s) with proportions	% of total C14
Stainless steel	NE		activity
Other ferrous metals			
Iron	~55.0	AETP defective plant stripped down metal	
Aluminium	NE		
Beryllium	NE		
Cobalt	NE		
Copper	NE		
Lead	NE		
Magnox/Magnesium	NE		
Nickel	NE		
Titanium	NE		
Uranium	NE		
Zinc	NE		
Zircaloy/Zirconium	NE		
Other metals	NE		
Organics (%wt): Halogenated plastic oil may be present.	cs and sma	all quantities of rubber and wood are also	present. Traces of
	(%wt)	Type(s) and comment	% of total C14
Total cellulosics	~5.0		activity
Paper, cotton	NE		
Wood	~5.0		
Halogenated plastics	~35.0		
Total non-halogenated plastics	NE		
Condensation polymers	NE		
Others	NE		
Organic ion exchange materials	NE		
Total rubber	~4.0		
Halogenated rubber	NE		
Non-halogenated rubber	NE		
Hydrocarbons	NE		
Oil or grease	NE		
Fuel	NE		
Asphalt/Tarmac (cont.coal tar)	NE		
Asphalt/Tarmac (no coal tar)	NE		
Bitumen	NE		
Others	NE		
Other organics	NE	sludge consisting of estuary silt plus trace oil	

Other materials (%wt):

		(%wt)	Type(s) and comment	% of total C14 activity
	Inorganic ion exchange materials	0		
	Inorganic sludges and flocs	0		
	Soil	NE		
	Brick/Stone/Rubble	NE		
	Cementitious material	0		
	Sand	NE		
	Glass/Ceramics	NE		
	Graphite	NE		
	Desiccants/Catalysts	NE		
	Asbestos	0		
	Non/low friable			
	Moderately friable			
	Highly friable			
	Free aqueous liquids	0		
	Free non-aqueous liquids	0		
	Powder/Ash	0		
Inorganic anic	ons (%wt): Not estimated but if	present th	nere would only be trace amounts.	
		(%wt)	Type(s) and comment	
	Fluoride	NE		
	Chloride	NE		
	lodide	NE		
	Cyanide	NE		
	Carbonate	NE		
	Nitrate	NE		
	Nitrite	NE		
	Phosphate	NE		
	Sulphate	NE		
	Sulphide	NE		
Materials of in waste accepta				
wasto assopte	ando ontona.	(%wt)	Type(s) and comment	
	Combustible metals	0	.,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	
	Low flash point liquids	0		
	Explosive materials	0		
	Phosphorus	0		
	Hydrides	0		
	Biological etc. materials	0		
	Biodegradable materials	0		
	Putrescible wastes	0		
	Name and the second sec	0		

4

Non-putrescible wastes.....

	Corrosive materials	0	
	Pyrophoric materials	0	
	Generating toxic gases	0	
	Reacting with water	0	
	Higher activity particles	0	Not expected
	Soluble solids as bulk chemical compounds	0	
Hazardous s	ubstances / - us pollutants:		
		(%wt)	Type(s) and comment
	Acrylamide	NE	
	Benzene	NE	
	Chlorinated solvents	NE	
	Formaldehyde	NE	
	Organometallics	NE	
	Phenol	NE	
	Styrene	NE	
	Tri-butyl phosphate	NE	
	Other organophosphates	NE	
	Vinyl chloride	NE	
	Arsenic	NE	
	Barium	NE	
	Boron	NE	
	Boron (in Boral)	NE	
	Boron (non-Boral)	NE	
	Cadmium	NE	
	Caesium	NE	
	Selenium	NE	
	Chromium	NE	
	Molybdenum	NE	
	Thallium	NE	
	Tin	NE	
	Vanadium	NE	
	Mercury compounds	NE	
	Others	NE	
	Electronic Electrical Equipment (EEE)		
	EEE Type 1	NE	
	EEE Type 2	NE	
	EEE Type 3	NE	
	EEE Type 4	NE	
	EEE Type 5	NE	

Complexing agents (%wt): Not yet determined

(%wt) Type(s) and comment

EDTA...... NE

DPTA...... NE

NTA...... NE

Polycarboxylic acids...... NE

Other organic complexants....... NE Not expected to be present but a trace quantity

may be present on detailed analysis.

Total complexing agents..... NE

Potential for the waste to contain discrete items:

Yes.

TREATMENT, PACKAGING AND DISPOSAL

Planned on-site / off-site treatment(s):

Treatment	On-site / Off site	Stream volume %
Low force compaction		
Supercompaction (HFC)	Off-site	~10.0
Incineration	Off-site	~40.0
Solidification		
Decontamination		
Metal treatment	Off-site	~40.0
Size reduction		
Decay storage		
Recyling / reuse		
Other / various		
None	Off-site	~10.0

Comment on planned treatments:

In line with the waste hierarchy, wastes will be treated preferentially by incineration, metal decontamination/melting, supercompaction, optimal packaging in HHISOs or immobilisation by encapsulation where necessary, prior to ultimate disposal at the LLW Repository. These treatments will be carried out off-site under contract with companies such as LLWR Ltd, Cyclife, Tradebe Inutec.

Disposal Routes:

Disposal Route	Stream volume %	Disposal density t/m3
Expected to be consigned to the LLW Repository	20.0	
Expected to be consigned to a Landfill Facility		
Expected to be consigned to an On-Site Disposal Facility		
Expected to be consigned to an Incineration Facility	40.0	
Expected to be consigned to a Metal Treatment Facility	40.0	
Expected to be consigned as Out of Scope		
Expected to be recycled / reused		
Disposal route not known		

Classification codes for waste expected to be consigned to a landfill facility:

Upcoming (2022/23-2024/25) Waste Routing (if expected to change from above):

Disposal Route	Stream volume %				
Disposal Noute	2022/23 2023/24 2024/2		2024/25		
Expected to be consigned to the LLW Repository Expected to be consigned to a Landfill Facility Expected to be consigned to an On-Site Disposal Facility Expected to be consigned to an Incineration Facility Expected to be consigned to a Metal Treatment Facility Expected to be consigned as Out of Scope Expected to be recycled / reused Disposal route not known					

Opportunities for alternative disposal routing:

Opportunity	Opportunity Confidence Comment
-------------	--------------------------------

Waste Packaging for Disposal:

Container	Stream volume %	Waste loading m ³	Number of packages
1/3 Height IP-1 ISO 2/3 Height IP-2 ISO 1/2 Height WAMAC IP-2 ISO 1/2 Height IP-2 Disposal/Re-usable ISO 2m box (no shielding) 4m box (no shielding) Other	20.0	~30.4	2

Other information: Waste loading is representative of the raw waste following further planned

treatments. Supercompaction assumed to reduce volume to 20% of original. Solidification assumed to increase volume to 300% of original. No treatment

results in the same volume.

Waste Planned for Disposal at the LLW Repository:

Container voidage: -

Comamor Voldago.

Waste Characterisation Form (WCH):

The waste meets the LLWR's Waste Acceptance Criteria (WAC).

orm (WCH): The waste has a current WCH.

Inventory information is consistent with the current WCH.

Waste consigned for disposal to LLWR in year of generation:

No. Efforts are made to dispose of waste during year of arising, but this is dependent on rate of arising throughout the year. This is also dependent on

consignment of waste to third parties.

Non-Containerised Waste for In-Vault Grouting: (Not applicable to this waste stream)

Stream volume (%):

Waste stream variation: -

Bounding cuboidal volume:

Inaccessible voidage: -

Other information:

RADIOACTIVITY

Source: Contamination will be main source of activity with possibly some activation of certain

reactor or fuel route components.

Uncertainty: Waste mapping is continuously carried out to monitor volumes of waste arising from plant

areas to ensure the ongoing accuracy of our fingerprints.

Definition of total alpha and total beta/gamma:

Where totals are shown on the table of radionuclide activities they are the sums of the listed beta/gamma emitting radionuclides plus 'other beta/gamma' not listed on the

datasheet.

Measurement of radioactivities:

Hinkley Point B sampling plan is based on BEG/FORM/SHE/ENVI/017/005 Routine Fingerprint Characterisation Plan. Sludge characterisation was carried out by Inutec who produced report X0386 - The radiochemical and chemical analysis of EDF oily sludge.

Other information:

	N	Mean radioact	ivity, TBq/m³			Mean radioactivity, TBq/m³			
Nuclide	Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code	Nuclide	Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code
H 3	5.65E-06	CC 2	5.65E-06	CC 2	Gd 153				
Be 10					Ho 163				
C 14	2.27E-07	CC 2	2.27E-07	CC 2	Ho 166m				
Na 22					Tm 170				
AI 26					Tm 171				
CI 36	2.10E-07	CC 2	2.10E-07	CC 2	Lu 174				
Ar 39					Lu 176				
Ar 42					Hf 178n				
K 40					Hf 182				
Ca 41					Pt 193				
Mn 53					TI 204				
Mn 54	2.64E-07	CC 2	2.64E-07	CC 2	Pb 205				
Fe 55	1.2E-05	CC 2	1.2E-05	CC 2	Pb 210				
Co 60	3.86E-06	CC 2	3.86E-06	CC 2	Bi 208				
Ni 59					Bi 210m				
Ni 63	1.17E-05	CC 2	1.17E-05	CC 2	Po 210				
Zn 65	6.95E-08	CC 2	6.95E-08	CC 2	Ra 223				
Se 79					Ra 225				
Kr 81					Ra 226 Ra 228				
Kr 85					Ac 227				
Rb 87	0.075.07	00.0	0.075.07	00.0	Th 227				
Sr 90	9.67E-07	CC 2	9.67E-07	CC 2	Th 228				
Zr 93					Th 229				
Nb 91 Nb 92					Th 230				
Nb 92 Nb 93m					Th 232				
Nb 94	3.08E-08	CC 2	3.08E-08	CC 2	Th 234				
Mo 93	3.00L-00	00 2	3.00L-00	00 2	Pa 231				
Tc 97					Pa 233				
Tc 99					U 232				
Ru 106	4.48E-07	CC 2	4.48E-07	CC 2	U 233				
Pd 107	1.102 01	00 2	1.102 07	00 2	U 234	1.08E-08	CC 2	1.08E-08	CC 2
Ag 108m	4.47E-08	CC 2	4.47E-08	CC 2	U 235	2.63E-10		2.63E-10	
Ag 110m	1.03E-07	CC 2	1.03E-07	CC 2	U 236	3.68E-09	CC 2	3.68E-09	CC 2
Cd 109		Ì			U 238	1.03E-08	CC 2	1.03E-08	CC 2
Cd 113m					Np 237				
Sn 119m					Pu 236				
Sn 121m					Pu 238	3.50E-07	CC 2	3.50E-07	CC 2
Sn 123					Pu 239	2.07E-07	CC 2	2.07E-07	CC 2
Sn 126					Pu 240	4.49E-07	CC 2	4.49E-07	CC 2
Sb 125	1.83E-07	CC 2	1.83E-07	CC 2	Pu 241	2.30E-05	CC 2	2.30E-05	CC 2
Sb 126					Pu 242				
Te 125m					Am 241	1.36E-06	CC 2	1.36E-06	CC 2
Te 127m					Am 242m				
I 129					Am 243		20 -		00 -
Cs 134	3.18E-07	CC 2	3.18E-07	CC 2	Cm 242	1.37E-08	CC 2	1.37E-08	CC 2
Cs 135					Cm 243	1.32E-09	CC 2	1.32E-09	CC 2
Cs 137	3.15E-05	CC 2	3.15E-05	CC 2	Cm 244	8.16E-08	CC 2	8.16E-08	CC 2
Ba 133	6.82E-08	CC 2	6.82E-08	CC 2	Cm 245				
La 137					Cm 246				
La 138	0.4== 0=	00.0	0.475.05	00.0	Cm 248				
Ce 144	2.47E-07	CC 2	2.47E-07	CC 2	Cf 249				
Pm 145	0.005.05	00.0	0.005.05	00.0	Cf 250				
Pm 147	3.26E-07	CC 2	3.26E-07	CC 2	Cf 251 Cf 252				
Sm 147					Other a				
Sm 151	4 405 07	00.0	4.405.05	00.0		1 17E 06	CC 2	1 175 06	CC 2
Eu 152	1.46E-07	CC 2	1.46E-07	CC 2	Other b/g Total a	1.17E-06		1.17E-06	CC 2
Eu 154	3.51E-07	CC 2	3.51E-07	CC 2	Total a	2.49E-06	CC 2 CC 2	2.49E-06	CC 2
Eu 155	6.42E-08	CC 2	6.42E-08	CC 2	rotar b/g	9.28E-05	00 2	9.28E-05	UU 2

Bands (Upper and Lower)

A a factor of 1.5 B a factor of 3 C a factor of 10 D a factor of 100

E a factor of 1000

Note: Bands quantify uncertainty in mean radioactivity.

Code

- 1 Measured activity
- 2 Derived activity (best estimate)
- 3 Derived activity (upper limit)
- 4 Not present
- 5 Present but not significant
- 6 Likely to be present but not assessed
- 7 Present in significant quantities but not determined 8 Not expected to be present in significant quantity