SITE Sizewell B

SITE OWNER EDFE NGL

WASTE CUSTODIAN EDFE NGL

WASTE TYPE LLW

Is the waste subject to

Scottish Policy:

No

WASTE VOLUMES

Reported Stocks: At 1.4.2022...... 120.1 m³

Future arisings - 1.4.2022 - 31.3.2035....... 390.0 m³

1.4.2035 - 31.3.2043....... 480.0 m³

Total future arisings: 870.0 m³

Total waste volume: 990.1 m³

Comment on volumes: Waste volumes will be variable depending on station operating conditions.

Uncertainty factors on Stock (upper): x 1.25 Arisings (upper) x 1.5

volumes: Stock (lower): x 0.75 Arisings (lower) x 0.5

WASTE SOURCE Hard and soft trash arising from power station operation and maintenance.

PHYSICAL CHARACTERISTICS

General description: A range of contaminated materials. The rates of arising for different materials will vary

through the cycle. Individual drums will not be representative of the stream averages.

Physical components (%wt): Plastics; Paper; Incinerator ash; Metallic Items; Clothing; Rubber; Filters; Redundant

Equipment; Glass; Wood. There are also drums containing the waste. The plastics, paper,

clothing and rubber are expected to be subjected to low force in-drum compaction.

Sealed sources: The waste does not contain sealed sources.

Bulk density (t/m³): ~1

Comment on density: Density refers to the density of the material as contained in 200 litre drums.

CHEMICAL COMPOSITION

General description and components (%wt):

Metal (2%wt), soil/rubble (1%wt), soft organics (10%wt), plastic/rubber (76%wt), wood

(1%wt), ash/cermaics/charcoal (10%wt).

Chemical state: Neutral

Chemical form of radionuclides:

H-3: In any residual moisture. Unlikely to be a significant fraction of the waste.

C-14: Trace (value unknown but not thought to be significant). Cl-36: Not expected to be present in any measurable quantity.

Se-79: Not expected to be present in any measurable quantity. Tc-99: Not expected to be present in any measurable quantity. I-129: Not expected to be present in any measurable quantity. Ra: Not expected to be present in any measurable quantity. Th: Not expected to be present in any measurable quantity.

U: Trace (value unknown but not thought to be significant), probably as oxide.

Np: Not expected to be present in any measurable quantity.

Pu: Trace (value unknown but not thought to be significant), probably as oxide.

Metals and alloys (%wt):

(%wt) Type(s) / Grade(s) with proportions % of total C14 activity

Cobalt..... NE

Copper	P		
Lead			
Magnox/Magnesium	•		
Nickel			
Titanium			
Uranium			
Zinc			
Zircaloy/Zirconium			
Other metals			
	paper and	I cotton. Other organics include charcoa	l granules PVC
	(%wt)	Type(s) and comment	% of total C14
Total cellulosics	~1.0		activity
Paper, cotton	~0		
Wood	~1.0		
Halogenated plastics	~0		
Total non-halogenated plastics	~57.0		
Condensation polymers	0		
Others	~57.0		
Organic ion exchange materials	0		
Total rubber	~9.0		
Halogenated rubber	~9.0		
Non-halogenated rubber	NE		
Hydrocarbons	NE		
Oil or grease	NE		
Fuel			
Asphalt/Tarmac (cont.coal tar)			
Asphalt/Tarmac (no coal tar)			
Bitumen			
Others			
Other organics	~5.0		
Other materials (%wt):			
	(%wt)	Type(s) and comment	% of total C14 activity
Inorganic ion exchange materials	0		•
Inorganic sludges and flocs	0		
Soil	1.0		
Brick/Stone/Rubble	~0		
Cementitious material	0		
Sand	NE		
Glass/Ceramics	~0		
Graphite	0		
Desiccants/Catalysts	0		

Asbestos	NE	
Non/low friable		
Moderately friable		
Highly friable		
Free aqueous liquids	0	
Free non-aqueous liquids	0	
Powder/Ash	0	
Inorganic anions (%wt): Not estimated but of	only trace q	uantities, if any, will be present.
, ,	(%wt)	
	(/owi)	Type(s) and comment
Fluoride	NE	
Chloride	NE	
lodide	NE	
Cyanide	NE	
Carbonate	NE	
Nitrate	NE	
Nitrite	NE	
Phosphate	NE	
Sulphate	NE	
Sulphide	NE	
	(%wt)	Type(s) and comment
Combustible metals	0	
Low flash point liquids	0	
Explosive materials	0	
Phosphorus	0	
Hydrides	0	
Biological etc. materials	0	
Biodegradable materials	0	
Putrescible wastes	0	
Non-putrescible wastes	NE	
Corrosive materials	0	
Pyrophoric materials	0	
Generating toxic gases	0	
Reacting with water	0	
Higher activity particles	0	
Soluble solids as bulk chemical compounds	0	
Hazardous substances / The waste might in non hazardous pollutants: items cannot be ma		small quantities of asbestos occasionally if specialised small asbestos free.
	(%wt)	Type(s) and comment
Acrylamide	NE	

Benzene	NE	
Chlorinated solvents	NE	
Formaldehyde	NE	
Organometallics	NE	
Phenol	NE	
Styrene	NE	
Tri-butyl phosphate	NE	
Other organophosphates	NE	
Vinyl chloride	NE	
Arsenic	NE	
Barium	NE	
Boron	NE	
Boron (in Boral)	NE	
Boron (non-Boral)	NE	
Cadmium	NE	
Caesium	NE	
Selenium	NE	
Chromium	NE	
Molybdenum	NE	
Thallium	NE	
Tin	NE	
Vanadium	NE	
Mercury compounds	NE	
Others	NE	
Electronic Electrical Equipment (EEE)		
EEE Type 1	NE	
EEE Type 2	NE	
EEE Type 3	NE	
EEE Type 4	NE	
EEE Type 5	NE	
Complexing agents (%wt): Not yet determined		
	(%wt)	Type(s) and comment
EDTA	NE	
DPTA	NE	
NTA	NE	
Polycarboxylic acids	NE	
Other organic complexants	NE	Not expected.
Total complexing agents	0	
Potential for the waste to No.		

contain discrete items:

Station Maintenance and Operations LLW

TREATMENT, PACKAGING AND DISPOSAL

Planned on-site / off-site treatment(s):

Treatment	On-site / Off site	Stream volume %
Low force compaction		
Supercompaction (HFC)	Off-site	~15.0
Incineration	Off-site	~45.0
Solidification		
Decontamination		
Metal treatment	Off-Site	~35.0
Size reduction		
Decay storage		
Recyling / reuse		
Other / various		
None	Off-site	~5.0

Comment on planned treatments:

In line with the waste hierarchy, wastes will be treated preferentially by incineration, metal decontamination/melting, supercompaction, optimal packaging in HHISOs or immobilisation by encapsulation where necessary, prior to ultimate disposal at the LLW Repository. These treatments will be carried out off-site under contract with companies such as LLWR Ltd, Cyclife, Tradebe Inutec.

Disposal Routes:

Disposal Route	Stream volume %	Disposal density t/m3
Expected to be consigned to the LLW Repository	20.0	
Expected to be consigned to a Landfill Facility		
Expected to be consigned to an On-Site Disposal Facility		
Expected to be consigned to an Incineration Facility	45.0	
Expected to be consigned to a Metal Treatment Facility	35.0	
Expected to be consigned as Out of Scope		
Expected to be recycled / reused		
Disposal route not known		

Classification codes for waste expected to be consigned to a landfill facility:

Upcoming (2022/23-2024/25) Waste Routing (if expected to change from above):

Disposal Route	Stream volume %				
Disposal Notice	2022/23	2023/24	2024/25		
Expected to be consigned to the LLW Repository Expected to be consigned to a Landfill Facility Expected to be consigned to an On-Site Disposal Facility Expected to be consigned to an Incineration Facility Expected to be consigned to a Metal Treatment Facility Expected to be consigned as Out of Scope Expected to be recycled / reused Disposal route not known					

Opportunities for alternative disposal routing:

Baseline Opportunity Stream Date that Opportunity Opportunity Opportunity Confidence will be realised Comment	
---	--

Waste Packaging for Disposal:

Container	Stream volume %	Waste loading m ³	Number of packages
1/3 Height IP-1 ISO 2/3 Height IP-2 ISO 1/2 Height WAMAC IP-2 ISO 1/2 Height IP-2 Disposal/Re-usable ISO 2m box (no shielding) 4m box (no shielding) Other	20.0	~45.7	5

Other information: Waste loading is representative of the raw waste following further planned

treatments. Supercompaction assumed to reduce volume to 20% of original. Solidification assumed to increase volume to 300% of original. No treatment

results in the same volume.

Waste Planned for Disposal at the LLW Repository:

Container voidage:

Waste Characterisation

The waste meets the LLWR's Waste Acceptance Criteria (WAC).

Form (WCH): The waste has a current WCH.

Inventory information is consistent with the current WCH.

Waste consigned for disposal to LLWR in year of generation:

Yes. Waste will normally be disposed of during year of arising, but this is dependent

on rate of arising throughout the year.

Non-Containerised Waste for In-Vault Grouting: (Not applicable to this waste stream)

Stream volume (%):

Waste stream variation: -

Bounding cuboidal volume:

Inaccessible voidage: -

Other information: -

RADIOACTIVITY

Source: Contamination will be main source of activity with possibly some activation of certain

reactor or fuel route components.

Uncertainty: The values quoted are indicative of the activities that may be expected.

Definition of total alpha and total beta/gamma:

Where totals are shown on the table of radionuclide activities they are the sums of the listed alpha or beta/gamma emitting radionuclides plus 'other alpha' or 'other beta/gamma'.

Measurement of radioactivities:

Activity values are based on fingerprint of waste stream.

Other information:

	N	lean radioac	tivity, TBq/m³				Mean radioa	ctivity, TBq/m³	
Nuclide	Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code	Nuclide	Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code
H 3	2E-07	CC 2	2E-07	CC 2	Gd 153	1.4.2022	Code	ansings	Code
Be 10	2L-07	8	2L-07	8	Ho 163				
C 14	2E-07	CC 2	2E-07	CC 2	Ho 166m				
Na 22		4		4	Tm 170				
AI 26		4		4	Tm 171				
CI 36		8		8	Lu 174				
Ar 39		-			Lu 176				
Ar 42					Hf 178n				
K 40					Hf 182				
Ca 41		8		8	Pt 193				
Mn 53					TI 204				
Mn 54	3.2E-06	CC 2	3.2E-06	CC 2	Pb 205				
Fe 55	6.4E-05	CC 2	6.4E-05	CC 2	Pb 210		8		8
Co 60	2.8E-05	CC 2	2.8E-05	CC 2	Bi 208				
Ni 59		8		8	Bi 210m				
Ni 63	1.6E-05	CC 2	1.6E-05	CC 2	Po 210		8		8
Zn 65	4E-07	CC 2	4E-07	CC 2	Ra 223				
Se 79		8		8	Ra 225		_		_
Kr 81					Ra 226		8		8
Kr 85					Ra 228				
Rb 87	05.05	0 0	05.05		Ac 227 Th 227				
Sr 90	<2E-07	C 3	<2E-07	C 3	Th 228				
Zr 93		8		8	Th 229		8		8
Nb 91					Th 230		8		8
Nb 92 Nb 93m		8		8	Th 232		8		8
Nb 94		8		8	Th 234		Ü		Ü
Mo 93		8		8	Pa 231		8		8
Tc 97		U		0	Pa 233				
Tc 99		8		8	U 232				
Ru 106		8		8	U 233		8		8
Pd 107		8		8	U 234	<4E-08	C 3	<4E-08	C 3
Ag 108m	4E-07	CC 2	4E-07	CC 2	U 235	<4E-08	C 3	<4E-08	C 3
Ag 110m	4E-07	CC 2	4E-07	CC 2	U 236	<4E-08	C 3	<4E-08	C 3
Cd 109					U 238	<4E-08	C 3	<4E-08	C 3
Cd 113m					Np 237		8		8
Sn 119m					Pu 236				
Sn 121m		8		8	Pu 238	<4E-08	C 3	<4E-08	C 3
Sn 123					Pu 239	<4E-08	C 3	<4E-08	C 3
Sn 126	05.00	8	07.00	8	Pu 240	<4E-08	C 3	<4E-08	C 3
Sb 125	2E-06	CC 2	2E-06	CC 2	Pu 241	<4E-06	C 3	<4E-06	C 3
Sb 126					Pu 242	_4E 00	8	-⁄1E ∩0	8
Te 125m Te 127m					Am 241 Am 242m	<4E-08	C 3 8	<4E-08	C 3 8
1e 127m I 129		8		8	Am 242m Am 243		8		8
Cs 134	<2E-07	C 3	<2E-07	C 3	Cm 242	<4E-08	C 3	<4E-08	C 3
Cs 135	\ZL-01	8	~ZL-01	8	Cm 243	<4E-08	C 3	<4E-08	C 3
Cs 137	8E-07	CC 2	8E-07	CC 2	Cm 244	<4E-08	C 3	<4E-08	C 3
Ba 133	02 0.		02 07		Cm 245		8		8
La 137					Cm 246		8		8
La 138					Cm 248				
Ce 144	<2E-07	C 3	<2E-07	C 3	Cf 249				
Pm 145					Cf 250				
Pm 147	<8E-07	C 3	<8E-07	C 3	Cf 251				
Sm 147					Cf 252				
Sm 151					Other a		6		6
Eu 152		8		8	Other b/g	1.68E-05	CC 2	1.68E-05	CC 2
Eu 154		8		8	Total a	<4.4E-07	C 3	<4.4E-07	C 3
Eu 155		8		8	Total b/g	1.38E-04	CC 2	1.38E-04	CC 2

Bands (Upper and Lower)

A a factor of 1.5 B a factor of 3 C a factor of 10

D a factor of 100 E a factor of 1000

Note: Bands quantify uncertainty in mean radioactivity.

Code

- Measured activity
 Derived activity (best estimate)
 Derived activity (upper limit)

- 4 Not present 5 Present but not significant
- 6 Likely to be present but not assessed 7 Present in significant quantities but not determined
- 8 Not expected to be present in significant quantity