

SITE	Torness		
SITE OWNER	EDFE NGL		
WASTE CUSTODIAN	EDFE NGL		
WASTE TYPE	ILW; SPD1		
Is the waste subject to Scottish Policy:	Yes		
WASTE VOLUMES	Reported		
Stocks:	At 1.4.2022.....	2.3 m ³	
Future arisings -	1.4.2022 - 31.3.2028.....	0.3 m ³	
	1.4.2028 - 31.3.2030.....	0.2 m ³	
	1.4.2030 - 31.3.2031.....	0.7 m ³	
Total future arisings:		1.2 m ³	
Total waste volume:		3.5 m ³	
Comment on volumes:	Waste volumes will be variable depending on station operating conditions.		
Uncertainty factors on volumes:	Stock (upper): x 1.25 Stock (lower): x 0.75	Arisings (upper) x 1.5 Arisings (lower) x 0.5	
WASTE SOURCE	Waste arises from spent (chemically exhausted) ion exchange resins.		
PHYSICAL CHARACTERISTICS			
General description:	Spent (chemically exhausted) IRN-150 ion exchange resins. Mixed bed resin. The waste will not contain any large items that require special handling.		
Physical components (%vol):	Ion exchange resin (>99%), sand (<1%).		
Sealed sources:	The waste does not contain sealed sources.		
Bulk density (t/m ³):	~1		
Comment on density:	Waste density is estimated.		
CHEMICAL COMPOSITION			
General description and components (%wt):	Predominantly organic ion exchange resins with a small quantity of sand.		
Chemical state:	Neutral		
Chemical form of radionuclides:	H-3: The waste is expected to contain some tritiated liquor. C-14: Not determined Cl-36: Not determined Se-79: Not expected to be significant Tc-99: Not expected to be significant I-129: Not expected to be significant Ra: Not determined Th: Not determined U: Not determined Np: Not determined Pu: Not determined		
Metals and alloys (%wt):	-		
	(%wt)	Type(s) / Grade(s) with proportions	% of total C14 activity
Stainless steel.....	0		
Other ferrous metals.....	0		
Iron.....	0		
Aluminium.....	0		
Beryllium.....	0		
Cobalt.....	0		

WASTE STREAM

4C06

Active Effluent Filtration Resin

Copper.....	0
Lead.....	0
Magnox/Magnesium.....	0
Nickel.....	0
Titanium.....	0
Uranium.....	0
Zinc.....	0
Zircaloy/Zirconium.....	0
Other metals.....	0

Organics (%wt): Proprietary ion-exchange resins (approx 35% dry weight, 65% absorbed water) The waste contains no halogenated rubbers or plastics.

	(%wt)	Type(s) and comment	% of total C14 activity
Total cellulosics.....	0		
Paper, cotton.....	0		
Wood.....	0		
Halogenated plastics	0		
Total non-halogenated plastics....	0		
Condensation polymers.....	0		
Others.....	0		
Organic ion exchange materials....	~99.0		
Total rubber.....	0		
Halogenated rubber	0		
Non-halogenated rubber.....	0		
Hydrocarbons.....	0		
Oil or grease			
Fuel.....			
Asphalt/Tarmac (cont.coal tar)...			
Asphalt/Tarmac (no coal tar)....			
Bitumen.....			
Others.....			
Other organics.....	0		

Other materials (%wt): -

	(%wt)	Type(s) and comment	% of total C14 activity
Inorganic ion exchange materials..	0		
Inorganic sludges and flocs.....	NE		
Soil.....	0		
Brick/Stone/Rubble.....	0		
Cementitious material.....	0		
Sand.....	<1.0		
Glass/Ceramics.....	0		
Graphite.....	0		
Desiccants/Catalysts.....	0		

WASTE STREAM

4C06

Active Effluent Filtration Resin

Asbestos.....	0
Non/low friable.....	
Moderately friable.....	
Highly friable.....	
Free aqueous liquids.....	NE
Free non-aqueous liquids.....	0
Powder/Ash.....	0

Inorganic anions (%wt): Waste contains spent ion exchange anions the individual components of which have not yet been determined.

	(%wt)	Type(s) and comment
Fluoride.....	NE	
Chloride.....	NE	
Iodide.....	NE	
Cyanide.....	NE	
Carbonate.....	NE	
Nitrate.....	NE	
Nitrite.....	NE	
Phosphate.....	NE	
Sulphate.....	NE	
Sulphide.....	NE	

Materials of interest for waste acceptance criteria: There are no hazardous materials present.

	(%wt)	Type(s) and comment
Combustible metals.....	0	
Low flash point liquids.....	0	
Explosive materials.....	0	
Phosphorus.....	0	
Hydrides.....	0	
Biological etc. materials.....	0	
Biodegradable materials.....	0	
Putrescible wastes.....	0	
Non-putrescible wastes.....	0	
Corrosive materials.....	0	
Pyrophoric materials.....	0	
Generating toxic gases.....	0	
Reacting with water.....	0	
Higher activity particles.....	P	May be present
Soluble solids as bulk chemical compounds.....	0	

WASTE STREAM**4C06****Active Effluent Filtration Resin**

Hazardous substances / non hazardous pollutants: The waste will not contain any listed substances.

	(%wt)	Type(s) and comment
Acrylamide.....	NE	
Benzene.....	NE	
Chlorinated solvents.....	NE	
Formaldehyde.....	NE	
Organometallics.....	NE	
Phenol.....	NE	
Styrene.....	NE	
Tri-butyl phosphate.....	NE	
Other organophosphates.....	NE	
Vinyl chloride.....	NE	
Arsenic.....	NE	
Barium.....	NE	
Boron.....	NE	
Boron (in Boral).....		
Boron (non-Boral).....		
Cadmium.....	NE	
Caesium.....	NE	
Selenium.....	NE	
Chromium.....	NE	
Molybdenum.....	NE	
Thallium.....	NE	
Tin.....	NE	
Vanadium.....	NE	
Mercury compounds.....	NE	
Others.....	NE	
Electronic Electrical Equipment (EEE)		
EEE Type 1.....	0	
EEE Type 2.....	0	
EEE Type 3.....	0	
EEE Type 4.....	0	
EEE Type 5.....	0	

Complexing agents (%wt): No

	(%wt)	Type(s) and comment
EDTA.....	NE	
DPTA.....	NE	
NTA.....	NE	
Polycarboxylic acids.....	NE	
Other organic complexants.....	NE	No known complexing agents are present in the waste.
Total complexing agents.....	NE	

Potential for the waste to contain discrete items: Yes.

PACKAGING AND CONDITIONING

Conditioning method: The waste is expected to be encapsulated in a BFS/OPC matrix. Other approaches under review are (1) wet oxidation followed by drying and supercompaction (2) drying and supercompaction. Drums of supercompacted waste would be grouted in an "enhanced" drum.

Plant Name: None.

Location: Torness Power Station.

Plant startup date: Between 2035 and 2038.

Total capacity (m³/y incoming waste): ~175.0

Target start date for packaging this stream: -

Throughput for this stream (m³/y incoming waste): -

Other information: All waste in a tank will be retrieved when a conditioning campaign is undertaken. It is expected there will be several campaigns.

Likely container type:	Container	Waste packaged (%vol)	Waste loading (m ³)	Payload (m ³)	Number of packages
	500 l drum	100.0	~0.2	0.47	18

Likely container type comment: -

Range in container waste volume: -

Other information on containers: Stainless Steel

Likely conditioning matrix: BFS/OPC

Other information: A 9:1 BFS/OPC matrix is expected to be used.

Conditioned density (t/m³): ~1.7

Conditioned density comment: Density may vary from 1.62 to 1.72 t/m³.

Other information on conditioning: Appropriate plant to be provided at the station in accordance with EDF Energy strategy.

Opportunities for alternative disposal routing: No

Baseline Management Route	Opportunity Management Route	Stream volume (%)	Estimated Date that Opportunity will be realised	Opportunity Confidence	Comment
-	-	-	-	-	-

RADIOACTIVITY

Source: Spent Ion Exchange resins. Contamination by activation products will be a main source of activity.

Uncertainty: The estimates are based on theoretical assessments. The values quoted are indicative of those expected after several years of operation and include an allowance for the additional activity that would arise if spalled activity is present.

WASTE STREAM**4C06****Active Effluent Filtration Resin**

Definition of total alpha
and total beta/gamma:

Where totals are shown on the table of radionuclide activities they are the sums of the listed alpha or beta/gamma emitting radionuclides plus 'other alpha' or 'other beta/gamma'.

Measurement of
radioactivities:

Theoretical assessment and limited tank sampling.

Other information:

-

WASTE STREAM

4C06

Active Effluent Filtration Resin

Nuclide	Mean radioactivity, TBq/m³				Nuclide	Mean radioactivity, TBq/m³			
	Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code		Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code
H 3	1.32E-06	CC 2	2.67E-06	CC 2	Gd 153				
Be 10					Ho 163				
C 14	4.25E-07	CC 2	4.25E-07	CC 2	Ho 166m				
Na 22		4		4	Tm 170				
Al 26		4		4	Tm 171				
Cl 36	6.1E-07	CC 2	6.1E-07	CC 2	Lu 174				
Ar 39					Lu 176				
Ar 42					Hf 178n				
K 40	<4.1E-06	C 3	<4.1E-06	C 3	Hf 182				
Ca 41					Pt 193				
Mn 53					Tl 204				
Mn 54	6.94E-04	CC 2	1.16E-02	CC 2	Pb 205				
Fe 55	1.49E-02	CC 2	1.22E-01	CC 2	Pb 210	3.8E-05	CC 2	5.78E-05	CC 2
Co 60	1.31E-03	CC 2	4.94E-03	CC 2	Bi 208				
Ni 59					Bi 210m				
Ni 63	2.03E-03	CC 2	2.03E-03	CC 2	Po 210				
Zn 65	<4.3E-06	C 3	<8.39E-05	C 3	Ra 223				
Se 79					Ra 225				
Kr 81					Ra 226	9.7E-05	CC 2	9.7E-05	CC 2
Kr 85					Ra 228				
Rb 87					Ac 227				
Sr 90	2.33E-04	CC 2	3.24E-04	CC 2	Th 227				
Zr 93					Th 228				
Nb 91					Th 229				
Nb 92					Th 230				
Nb 93m					Th 232				
Nb 94	<4.4E-06	C 3	4.4E-06	C 3	Th 234	6.7E-05	CC 2	2.01E-03	CC 2
Mo 93					Pa 231				
Tc 97					Pa 233	6.5E-06	CC 2	1.95E-04	CC 2
Tc 99					U 232				
Ru 106	<5E-05	C 3	7.40E-04	C 3	U 233				
Pd 107					U 234	1.1E-07	CC 2	1.1E-07	CC 2
Ag 108m	2E-06	CC 2	2E-06	CC 2	U 235	5.8E-08	CC 2	5.8E-08	CC 2
Ag 110m	4.5E-06	CC 2	8.55E-05	CC 2	U 236				
Cd 109					U 238	6.5E-08	CC 2	6.5E-08	CC 2
Cd 113m					Np 237	1.9E-05	CC 2	1.9E-05	CC 2
Sn 119m					Pu 236				
Sn 121m					Pu 238	2E-05	CC 2	2.24E-05	CC 2
Sn 123					Pu 239	6		6	
Sn 126					Pu 240	<3.23E-05	CC 2	<3.23E-05	CC 2
Sb 125	<2.5E-05	C 3	1.65E-04	C 3	Pu 241	1.31E-03	CC 2	2.42E-03	CC 2
Sb 126					Pu 242	<8.3E-07	CC 2	<8.3E-07	CC 2
Te 125m					Am 241	9.04E-05	CC 2	9.04E-05	CC 2
Te 127m					Am 242m				
I 129					Am 243				
Cs 134	1.16E-03	CC 2	9.94E-03	CC 2	Cm 242	4.2E-07	CC 2	9.90E-06	CC 2
Cs 135					Cm 243	5.85E-06	CC 2	8.07E-06	CC 2
Cs 137	3.39E-02	CC 2	4.64E-02	CC 2	Cm 244	5.85E-06	CC 2	9.65E-06	CC 2
Ba 133					Cm 245				
La 137					Cm 246				
La 138					Cm 248				
Ce 144	1.4E-05	CC 2	2.47E-04	CC 2	Cf 249				
Pm 145					Cf 250				
Pm 147	2.65E-04	CC 2	1.86E-03	CC 2	Cf 251				
Sm 147					Cf 252				
Sm 151	1.6E-05	CC 2	1.78E-05	CC 2	Other a	1.42E-03	CC 2	1.42E-03	CC 2
Eu 152	<5.3E-06	C 3	1.01E-05	C 3	Other b/g	7.19E-05	CC 2	7.19E-05	CC 2
Eu 154	4.22E-05	CC 2	1.08E-04	CC 2	Total a	1.69E-03	CC 2	1.71E-03	CC 2
Eu 155	2.56E-05	CC 2	1.05E-04	CC 2	Total b/g	5.62E-02	CC 2	2.06E-01	CC 2

Bands (Upper and Lower)

A a factor of 1.5

B a factor of 3

C a factor of 10

D a factor of 100

E a factor of 1000

Note: Bands quantify uncertainty in mean radioactivity.

Code

1 Measured activity

2 Derived activity (best estimate)

3 Derived activity (upper limit)

4 Not present

5 Present but not significant

6 Likely to be present but not assessed

7 Present in significant quantities but not determined

8 Not expected to be present in significant quantity