

<b>WASTE STREAM</b>	<b>9A313</b>	<b>Stainless Steel (Reactor) LLW</b>
---------------------	--------------	--------------------------------------

**SITE** Berkeley  
**SITE OWNER** Nuclear Decommissioning Authority

**WASTE CUSTODIAN** Magnox Limited

**WASTE TYPE** LLW

Is the waste subject to Scottish Policy: No

**WASTE VOLUMES**

		Reported
Stocks:	At 1.4.2022.....	0 m <sup>3</sup>
Future arisings -	1.4.2074 - 31.3.2077.....	6.6 m <sup>3</sup>
Total future arisings:		6.6 m <sup>3</sup>
Total waste volume:		6.6 m <sup>3</sup>

Comment on volumes: Waste arisings are assumed to occur at a uniform rate over 3 years Final Dismantling & Site Clearance is assumed to commence in 2070 with reactor dismantling commencing in 2074 and lasting for 3 years. The volumes and radioactivity have been calculated for 85 years after reactor shutdown, i.e. 2074.

Uncertainty factors on volumes: Stock (upper): x Arisings (upper) x 1.2  
 Stock (lower): x Arisings (lower) x 0.8

**WASTE SOURCE** Stainless steel items from reactor dismantling.

**PHYSICAL CHARACTERISTICS**

General description: A variety of stainless steel items including BSD piping and ducts.  
 Physical components (%vol): Stainless steel items (100%).  
 Sealed sources: The waste does not contain sealed sources.  
 Bulk density (t/m<sup>3</sup>): ~1.4  
 Comment on density: The density is of the waste as cut for packaging.

**CHEMICAL COMPOSITION**

General description and components (%wt): Stainless steels (100%).  
 Chemical state: Neutral  
 Chemical form of radionuclides: C-14: The carbon 14 is incorporated in the steel. There may also be some contamination as graphite.  
 Cl-36: The chlorine 36 is incorporated in the steel.  
 U: .  
 Metals and alloys (%wt): Items have been cut for packaging. Thicknesses are likely to vary from a few mm to about 25 mm.

	(%wt)	Type(s) / Grade(s) with proportions	% of total C14 activity
Stainless steel.....	100.0	All of the waste included in this waste stream is stainless steel, EN58B.	100.0
Other ferrous metals.....	0		
Iron.....			
Aluminium.....	0		
Beryllium.....	0		
Cobalt.....			
Copper.....	0		
Lead.....	0		
Magnox/Magnesium.....	0		

<b>WASTE STREAM</b>	<b>9A313</b>	<b>Stainless Steel (Reactor) LLW</b>
---------------------	--------------	--------------------------------------

Nickel.....

Titanium.....

Uranium.....

Zinc..... 0

Zircaloy/Zirconium..... 0

Other metals..... 0      There are no "other" metals.

Organics (%wt):      None expected. No halogenated plastics or rubbers will be present.

	(%wt)	Type(s) and comment	% of total C14 activity
Total cellulosics.....	0		
Paper, cotton.....	0		
Wood.....	0		
Halogenated plastics .....	0		
Total non-halogenated plastics.....	0		
Condensation polymers.....	0		
Others.....	0		
Organic ion exchange materials....	0		
Total rubber.....	0		
Halogenated rubber .....	0		
Non-halogenated rubber.....	0		
Hydrocarbons.....			
Oil or grease .....			
Fuel.....			
Asphalt/Tarmac (cont.coal tar)...			
Asphalt/Tarmac (no coal tar)....			
Bitumen.....			
Others.....			
Other organics.....	0		

Other materials (%wt):      Some graphite dust may be associated with reactor materials.

	(%wt)	Type(s) and comment	% of total C14 activity
Inorganic ion exchange materials..	0		
Inorganic sludges and flocs.....	0		
Soil.....	0		
Brick/Stone/Rubble.....	0		
Cementitious material.....	0		
Sand.....			
Glass/Ceramics.....	0		
Graphite.....	TR		
Desiccants/Catalysts.....			
Asbestos.....	0		
Non/low friable.....			
Moderately friable.....			

<b>WASTE STREAM</b>	<b>9A313</b>	<b>Stainless Steel (Reactor) LLW</b>
---------------------	--------------	--------------------------------------

Highly friable.....  
 Free aqueous liquids..... 0  
 Free non-aqueous liquids..... 0  
 Powder/Ash..... 0

Inorganic anions (%wt): Trace quantities of chloride may be present.

	(%wt)	Type(s) and comment
Fluoride.....	0	
Chloride.....	TR	
Iodide.....	0	
Cyanide.....	0	
Carbonate.....	0	
Nitrate.....	0	
Nitrite.....	0	
Phosphate.....	0	
Sulphate.....	0	
Sulphide.....	0	

Materials of interest for waste acceptance criteria: No materials likely to pose a fire or other non-radiological hazard have been identified.

	(%wt)	Type(s) and comment
Combustible metals.....	0	
Low flash point liquids.....	0	
Explosive materials.....	0	
Phosphorus.....	0	
Hydrides.....	0	
Biological etc. materials.....	0	
Biodegradable materials.....		
Putrescible wastes.....	0	
Non-putrescible wastes.....		
Corrosive materials.....	0	
Pyrophoric materials.....	0	
Generating toxic gases.....	0	
Reacting with water.....	0	
Higher activity particles.....		
Soluble solids as bulk chemical compounds.....		

Hazardous substances / non hazardous pollutants: If any, present in trace quantities only.

	(%wt)	Type(s) and comment
Acrylamide.....		
Benzene.....		
Chlorinated solvents.....		
Formaldehyde.....		

<b>WASTE STREAM</b>	<b>9A313</b>	<b>Stainless Steel (Reactor) LLW</b>
---------------------	--------------	--------------------------------------

Organometallics.....  
 Phenol.....  
 Styrene.....  
 Tri-butyl phosphate.....  
 Other organophosphates.....  
 Vinyl chloride.....  
 Arsenic.....  
 Barium.....  
 Boron.....  
     Boron (in Boral).....  
     Boron (non-Boral).....  
 Cadmium.....  
 Caesium.....  
 Selenium.....  
 Chromium.....  
 Molybdenum.....  
 Thallium.....  
 Tin.....  
 Vanadium.....  
 Mercury compounds.....  
 Others.....  
 Electronic Electrical Equipment (EEE)  
     EEE Type 1.....  
     EEE Type 2.....  
     EEE Type 3.....  
     EEE Type 4.....  
     EEE Type 5.....

Complexing agents (%wt):      Yes

(%wt)      Type(s) and comment

EDTA.....  
 DPTA.....  
 NTA.....  
 Polycarboxylic acids.....  
 Other organic complexants.....  
 Total complexing agents.....      TR

Potential for the waste to contain discrete items:      Yes. Large Metal Items (LMIs)/"substantial" thickness items considered "durable" assumed DIs; All stainless items assumed DIs. NB if recycled then DI Limits n/a

**TREATMENT, PACKAGING AND DISPOSAL**

**WASTE STREAM 9A313 Stainless Steel (Reactor) LLW**

Planned on-site / off-site treatment(s):

Treatment	On-site / Off site	Stream volume %
Low force compaction Supercompaction (HFC) Incineration Solidification Decontamination Metal treatment Size reduction Decay storage Recycling / reuse Other / various None		100.0

Comment on planned treatments:

This waste stream is expected to be sent for Metal Recycle.

**Disposal Routes:**

Disposal Route	Stream volume %	Disposal density t/m3
Expected to be consigned to the LLW Repository Expected to be consigned to a Landfill Facility Expected to be consigned to an On-Site Disposal Facility Expected to be consigned to an Incineration Facility Expected to be consigned to a Metal Treatment Facility Expected to be consigned as Out of Scope Expected to be recycled / reused Disposal route not known	100.0	1.4

Classification codes for waste expected to be consigned to a landfill facility: -

**Upcoming (2022/23-2024/25) Waste Routing (if expected to change from above):**

Disposal Route	Stream volume %		
	2022/23	2023/24	2024/25
Expected to be consigned to the LLW Repository Expected to be consigned to a Landfill Facility Expected to be consigned to an On-Site Disposal Facility Expected to be consigned to an Incineration Facility Expected to be consigned to a Metal Treatment Facility Expected to be consigned as Out of Scope Expected to be recycled / reused Disposal route not known			

**Opportunities for alternative disposal routing:** -

Baseline Management Route	Opportunity Management Route	Stream volume (%)	Estimated Date that Opportunity will be realised	Opportunity Confidence	Comment
-	-	-	-	-	-

**Waste Packaging for Disposal:** (Not applicable to this waste stream)

**WASTE STREAM      9A313      Stainless Steel (Reactor) LLW**

Container	Stream volume %	Waste loading m <sup>3</sup>	Number of packages
1/3 Height IP-1 ISO			
2/3 Height IP-2 ISO			
1/2 Height WAMAC IP-2 ISO			
1/2 Height IP-2 Disposal/Re-usable ISO			
2m box (no shielding)			
4m box (no shielding)			
Other			

Other information: -

**Waste Planned for Disposal at the LLW Repository:** (Not applicable to this waste stream)

Container voidage: -

Waste Characterisation Form (WCH): -

Waste consigned for disposal to LLWR in year of generation: -

**Non-Containerised Waste for In-Vault Grouting:** (Not applicable to this waste stream)

Stream volume (%): -

Waste stream variation: -

Bounding cuboidal volume:

Inaccessible voidage: -

Other information: -

**RADIOACTIVITY**

Source: Activation of the stainless steel and impurities.

Uncertainty: The values quoted were derived by calculation from available material specification and are indicative of the activities that are expected. The major source of uncertainty is the impurity levels.

Definition of total alpha and total beta/gamma: Where totals are shown on the table of radionuclide activities they are the sums of the listed alpha or beta/gamma emitting radionuclides plus 'other alpha' or 'other beta/gamma'.

Measurement of radioactivities: Specific Activities have been estimated using a neutron activation calculation.

Other information: The activities quoted are those at 85 years after reactor shutdown, i.e. in 2074. There may be some contamination by Cs137.

**WASTE STREAM 9A313 Stainless Steel (Reactor) LLW**

Nuclide	Mean radioactivity, TBq/m <sup>3</sup>				Nuclide	Mean radioactivity, TBq/m <sup>3</sup>			
	Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code		Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code
H 3				8	Gd 153				8
Be 10				8	Ho 163				8
C 14			1.37E-05	CC 2	Ho 166m				8
Na 22					Tm 170				8
Al 26					Tm 171				8
Cl 36			1.46E-09	CC 2	Lu 174				8
Ar 39				8	Lu 176				8
Ar 42				8	Hf 178n				8
K 40				8	Hf 182				8
Ca 41				8	Pt 193				8
Mn 53				8	Tl 204				8
Mn 54				8	Pb 205				8
Fe 55				8	Pb 210				8
Co 60			3.57E-07	CC 2	Bi 208				8
Ni 59			3.55E-05	CC 2	Bi 210m				8
Ni 63			2.14E-03	CC 2	Po 210				8
Zn 65				8	Ra 223				8
Se 79				8	Ra 225				8
Kr 81				8	Ra 226				8
Kr 85				8	Ra 228				8
Rb 87				8	Ac 227				8
Sr 90				8	Th 227				8
Zr 93				8	Th 228				8
Nb 91				8	Th 229				8
Nb 92				8	Th 230				8
Nb 93m				8	Th 232				8
Nb 94			6.87E-08	CC 2	Th 234				8
Mo 93			4.54E-08	CC 2	Pa 231				8
Tc 97				8	Pa 233				8
Tc 99			9.81E-09	CC 2	U 232				8
Ru 106				8	U 233				8
Pd 107				8	U 234				8
Ag 108m			4.61E-09	CC 2	U 235				8
Ag 110m				8	U 236				8
Cd 109				8	U 238				8
Cd 113m				8	Np 237				8
Sn 119m				8	Pu 236				8
Sn 121m				8	Pu 238				8
Sn 123				8	Pu 239				8
Sn 126				8	Pu 240				8
Sb 125				8	Pu 241				8
Sb 126				8	Pu 242				8
Te 125m				8	Am 241				8
Te 127m				8	Am 242m				8
I 129				8	Am 243				8
Cs 134				8	Cm 242				8
Cs 135				8	Cm 243				8
Cs 137				6	Cm 244				8
Ba 133				8	Cm 245				8
La 137				8	Cm 246				8
La 138				8	Cm 248				8
Ce 144				8	Cf 249				8
Pm 145				8	Cf 250				8
Pm 147				8	Cf 251				8
Sm 147				8	Cf 252				8
Sm 151				8	Other a				
Eu 152				8	Other b/g				
Eu 154				8	<b>Total a</b>	<b>0</b>		<b>0</b>	
Eu 155				8	<b>Total b/g</b>	<b>0</b>	<b>2.19E-03</b>	<b>CC 2</b>	

**Bands (Upper and Lower)**

- A a factor of 1.5
- B a factor of 3
- C a factor of 10
- D a factor of 100
- E a factor of 1000

Note: Bands quantify uncertainty in mean radioactivity.

**Code**

- 1 Measured activity
- 2 Derived activity (best estimate)
- 3 Derived activity (upper limit)
- 4 Not present
- 5 Present but not significant
- 6 Likely to be present but not assessed
- 7 Present in significant quantities but not determined
- 8 Not expected to be present in significant quantity