

<b>WASTE STREAM</b>	<b>9C325</b>	<b>Thermal Insulation (Asbestos) LLW</b>
---------------------	--------------	--

**SITE** Dungeness A  
**SITE OWNER** Nuclear Decommissioning Authority

**WASTE CUSTODIAN** Magnox Limited

**WASTE TYPE** LLW

Is the waste subject to Scottish Policy: No

**WASTE VOLUMES**

		Reported
Stocks:	At 1.4.2022.....	0 m <sup>3</sup>
Future arisings -	1.4.2092 - 31.3.2095.....	603.0 m <sup>3</sup>
Total future arisings:		603.0 m <sup>3</sup>
Total waste volume:		603.0 m <sup>3</sup>
Comment on volumes:	For inventory purposes the arisings are assumed to arise at a uniform rate over three years. Final Dismantling & Site Clearance is assumed to commence in 2088 with reactor dismantling commencing in 2092 and lasting for 3 years. The volumes and radioactivity have been calculated for 85 years after reactor shutdown, i.e. 2091.	
Uncertainty factors on volumes:	Stock (upper): x	Arisings (upper) x 1.2
	Stock (lower): x	Arisings (lower) x 0.8

**WASTE SOURCE** Insulation material from plant dismantling.

**PHYSICAL CHARACTERISTICS**

General description: Insulation materials.  
 Physical components (%vol): Insulating materials (100%).  
 Sealed sources: The waste does not contain sealed sources.  
 Bulk density (t/m<sup>3</sup>): ~1  
 Comment on density: The density is of the waste as prepared for packaging.

**CHEMICAL COMPOSITION**

General description and components (%wt): Insulation materials.  
 Chemical state: Neutral  
 Chemical form of radionuclides: H-3: The chemical form of tritium has not been assessed.  
 C-14: The chemical form of carbon 14 has not been assessed but may be graphite.  
 Cl-36: The chemical form of chlorine 36 has not been assessed.  
 Se-79: The selenium content is insignificant.  
 Tc-99: The technetium content is insignificant.  
 Ra: The radium content is insignificant.  
 Th: The thorium content is insignificant.  
 U: The uranium content is insignificant.  
 Np: The neptunium content is insignificant.  
 Pu: The plutonium content is insignificant.

Metals and alloys (%wt): -

	(%wt)	Type(s) / Grade(s) with proportions	% of total C14 activity
Stainless steel.....	0		
Other ferrous metals.....	0		
Iron.....			
Aluminium.....	NE		
Beryllium.....	0		
Cobalt.....			
Copper.....	0		

<b>WASTE STREAM</b>	<b>9C325</b>	<b>Thermal Insulation (Asbestos) LLW</b>
---------------------	--------------	--

Lead.....	0
Magnox/Magnesium.....	0
Nickel.....	
Titanium.....	
Uranium.....	
Zinc.....	0
Zircaloy/Zirconium.....	0
Other metals.....	0

Organics (%wt):                      Plastics may be expected. Halogenated rubbers are not expected. Halogenated plastics have not been estimated.

	(%wt)	Type(s) and comment	% of total C14 activity
Total cellulosics.....	~0		
Paper, cotton.....	0		
Wood.....	0		
Halogenated plastics .....	NE		
Total non-halogenated plastics.....	NE		
Condensation polymers.....	NE		
Others.....	NE		
Organic ion exchange materials....	0		
Total rubber.....	0		
Halogenated rubber .....	0		
Non-halogenated rubber.....	0		
Hydrocarbons.....			
Oil or grease .....			
Fuel.....			
Asphalt/Tarmac (cont.coal tar)...			
Asphalt/Tarmac (no coal tar)....			
Bitumen.....			
Others.....			
Other organics.....	0		

Other materials (%wt):                      There might be traces of graphite.

	(%wt)	Type(s) and comment	% of total C14 activity
Inorganic ion exchange materials..	0		
Inorganic sludges and flocs.....	0		
Soil.....	0		
Brick/Stone/Rubble.....	0		
Cementitious material.....	0		
Sand.....			
Glass/Ceramics.....	100.0	MMMF (Man Made Mineral Fibre) insulation material	
Graphite.....	0		
Desiccants/Catalysts.....			

<b>WASTE STREAM</b>	<b>9C325</b>	<b>Thermal Insulation (Asbestos) LLW</b>
---------------------	--------------	--

Asbestos.....	NE
Non/low friable.....	NE
Moderately friable.....	NE
Highly friable.....	NE
Free aqueous liquids.....	0
Free non-aqueous liquids.....	0
Powder/Ash.....	0

Inorganic anions (%wt): -

	(%wt)	Type(s) and comment
Fluoride.....	0	
Chloride.....	0	
Iodide.....	0	
Cyanide.....	0	
Carbonate.....	0	
Nitrate.....	0	
Nitrite.....	0	
Phosphate.....	0	
Sulphate.....	0	
Sulphide.....	0	

Materials of interest for waste acceptance criteria: The presence or absence of asbestos has yet to be confirmed.

	(%wt)	Type(s) and comment
Combustible metals.....	0	
Low flash point liquids.....	0	
Explosive materials.....	0	
Phosphorus.....	0	
Hydrides.....	0	
Biological etc. materials.....	0	
Biodegradable materials.....		
Putrescible wastes.....	0	
Non-putrescible wastes.....		
Corrosive materials.....	0	
Pyrophoric materials.....	0	
Generating toxic gases.....	0	
Reacting with water.....	0	
Higher activity particles.....		
Soluble solids as bulk chemical compounds.....		

Hazardous substances / non hazardous pollutants: -

	(%wt)	Type(s) and comment
Acrylamide.....		

<b>WASTE STREAM</b>	<b>9C325</b>	<b>Thermal Insulation (Asbestos) LLW</b>
---------------------	--------------	--

- Benzene.....
- Chlorinated solvents.....
- Formaldehyde.....
- Organometallics.....
- Phenol.....
- Styrene.....
- Tri-butyl phosphate.....
- Other organophosphates.....
- Vinyl chloride.....
- Arsenic.....
- Barium.....
- Boron.....
  - Boron (in Boral).....
  - Boron (non-Boral).....
- Cadmium.....
- Caesium.....
- Selenium.....
- Chromium.....
- Molybdenum.....
- Thallium.....
- Tin.....
- Vanadium.....
- Mercury compounds.....
- Others.....
- Electronic Electrical Equipment (EEE)
  - EEE Type 1.....
  - EEE Type 2.....
  - EEE Type 3.....
  - EEE Type 4.....
  - EEE Type 5.....

Complexing agents (%wt):      Yes

(%wt)      Type(s) and comment

- EDTA.....
- DPTA.....
- NTA.....
- Polycarboxylic acids.....
- Other organic complexants.....
- Total complexing agents.....      TR

Potential for the waste to contain discrete items:      No. In & of itself not a DI. If LLW then assumed drummed (ungroued) & compacted so not DI (unless drums are groued instead).

**WASTE STREAM 9C325 Thermal Insulation (Asbestos) LLW**

**TREATMENT, PACKAGING AND DISPOSAL**

Planned on-site / off-site treatment(s):

Treatment	On-site / Off site	Stream volume %
Low force compaction Supercompaction (HFC) Incineration Solidification Decontamination Metal treatment Size reduction Decay storage Recycling / reuse Other / various None		100.0

Comment on planned treatments:

-

**Disposal Routes:**

Disposal Route	Stream volume %	Disposal density t/m3
Expected to be consigned to the LLW Repository Expected to be consigned to a Landfill Facility Expected to be consigned to an On-Site Disposal Facility Expected to be consigned to an Incineration Facility Expected to be consigned to a Metal Treatment Facility Expected to be consigned as Out of Scope Expected to be recycled / reused Disposal route not known	100.0	1.0

Classification codes for waste expected to be consigned to a landfill facility: 17 06 01\*, 17 06 03\*, 17 06 04

**Upcoming (2022/23-2024/25) Waste Routing (if expected to change from above):**

Disposal Route	Stream volume %		
	2022/23	2023/24	2024/25
Expected to be consigned to the LLW Repository Expected to be consigned to a Landfill Facility Expected to be consigned to an On-Site Disposal Facility Expected to be consigned to an Incineration Facility Expected to be consigned to a Metal Treatment Facility Expected to be consigned as Out of Scope Expected to be recycled / reused Disposal route not known			

**Opportunities for alternative disposal routing:** -

Baseline Management Route	Opportunity Management Route	Stream volume (%)	Estimated Date that Opportunity will be realised	Opportunity Confidence	Comment
-	-	-	-	-	-

**Waste Packaging for Disposal:** (Not applicable to this waste stream)

**WASTE STREAM      9C325      Thermal Insulation (Asbestos) LLW**

Container	Stream volume %	Waste loading m <sup>3</sup>	Number of packages
1/3 Height IP-1 ISO			
2/3 Height IP-2 ISO			
1/2 Height WAMAC IP-2 ISO			
1/2 Height IP-2 Disposal/Re-usable ISO			
2m box (no shielding)			
4m box (no shielding)			
Other			

Other information: -

**Waste Planned for Disposal at the LLW Repository:** (Not applicable to this waste stream)

Container voidage: -

Waste Characterisation Form (WCH): -

Waste consigned for disposal to LLWR in year of generation: -

**Non-Containerised Waste for In-Vault Grouting:** (Not applicable to this waste stream)

Stream volume (%): -

Waste stream variation: -

Bounding cuboidal volume:

Inaccessible voidage: -

Other information: -

**RADIOACTIVITY**

Source: Activation of the materials and impurities. There may be some contamination.

Uncertainty: Only very approximate estimates have been made of the total specific activities. The activities quoted are those at the time of Final Dismantling & Site Clearance.

Definition of total alpha and total beta/gamma: Where totals are shown on the table of radionuclide activities they are the sums of the listed alpha or beta/gamma emitting radionuclides plus 'other alpha' or 'other beta/gamma'.

Measurement of radioactivities: The specific activities of the reactor material were assumed to be the same as Trawsfynydd.

Other information: The activities quoted are those at 85 years after reactor shutdown, i.e. in 2091. There may be some contamination by Cs137.

**WASTE STREAM 9C325 Thermal Insulation (Asbestos) LLW**

Nuclide	Mean radioactivity, TBq/m <sup>3</sup>				Nuclide	Mean radioactivity, TBq/m <sup>3</sup>			
	Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code		Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code
H 3			3.5E-05	CC 2	Gd 153				8
Be 10				8	Ho 163				8
C 14			6.75E-05	CC 2	Ho 166m				8
Na 22				8	Tm 170				8
Al 26			1E-06	CC 2	Tm 171				8
Cl 36			1.11E-06	CC 2	Lu 174				8
Ar 39				8	Lu 176				8
Ar 42				8	Hf 178n				8
K 40				8	Hf 182				8
Ca 41			1.41E-05	CC 2	Pt 193				8
Mn 53				8	Tl 204				8
Mn 54				8	Pb 205				8
Fe 55				8	Pb 210				8
Co 60			2.67E-08	CC 2	Bi 208				8
Ni 59				8	Bi 210m				8
Ni 63			2.58E-05	CC 2	Po 210				8
Zn 65				8	Ra 223				8
Se 79				8	Ra 225				8
Kr 81				8	Ra 226				8
Kr 85				8	Ra 228				8
Rb 87				8	Ac 227				8
Sr 90				8	Th 227				8
Zr 93				8	Th 228				8
Nb 91				8	Th 229				8
Nb 92				8	Th 230				8
Nb 93m				6	Th 232				8
Nb 94			1.45E-09	CC 2	Th 234				8
Mo 93			1.16E-08	CC 2	Pa 231				8
Tc 97				8	Pa 233				8
Tc 99				6	U 232				8
Ru 106				8	U 233				8
Pd 107				8	U 234				8
Ag 108m				6	U 235				8
Ag 110m				8	U 236				8
Cd 109				8	U 238				8
Cd 113m				8	Np 237				8
Sn 119m				8	Pu 236				8
Sn 121m				6	Pu 238				8
Sn 123				8	Pu 239				8
Sn 126				8	Pu 240				8
Sb 125				8	Pu 241				8
Sb 126				8	Pu 242				8
Te 125m				8	Am 241				8
Te 127m				8	Am 242m				8
I 129				8	Am 243				8
Cs 134				8	Cm 242				8
Cs 135				8	Cm 243				8
Cs 137				6	Cm 244				8
Ba 133			2.54E-08	CC 2	Cm 245				8
La 137				8	Cm 246				8
La 138				8	Cm 248				8
Ce 144				8	Cf 249				8
Pm 145				8	Cf 250				8
Pm 147				8	Cf 251				8
Sm 147				8	Cf 252				8
Sm 151			1.78E-06	CC 2	Other a				
Eu 152			7.13E-06	CC 2	Other b/g				
Eu 154			1.13E-07	CC 2	<b>Total a</b>	<b>0</b>	<b>0</b>		
Eu 155				8	<b>Total b/g</b>	<b>0</b>	<b>1.54E-04</b>	<b>CC 2</b>	

**Bands (Upper and Lower)**

- A a factor of 1.5
- B a factor of 3
- C a factor of 10
- D a factor of 100
- E a factor of 1000

Note: Bands quantify uncertainty in mean radioactivity.

**Code**

- 1 Measured activity
- 2 Derived activity (best estimate)
- 3 Derived activity (upper limit)
- 4 Not present
- 5 Present but not significant
- 6 Likely to be present but not assessed
- 7 Present in significant quantities but not determined
- 8 Not expected to be present in significant quantity