WASTE STREAM 9C35 Miscellaneous Activated Components

SITE Dungeness A

SITE OWNER **Nuclear Decommissioning Authority**

WASTE CUSTODIAN Magnox Limited

ILW; SPD3 **WASTE TYPE**

Is the waste subject to

Scottish Policy:

Nο

WASTE VOLUMES

Reported

Stocks: At 1.4.2022..... $6.2 \, \text{m}^3$

Total future arisings: $0 \, \text{m}^3$

Total waste volume: 6.2 m³

Comment on volumes: The station ceased generation on 31/12/2006.

Uncertainty factors on Stock (upper): x 1.2 Arisings (upper) volumes: Stock (lower): Arisings (lower)

WASTE SOURCE Redundant or defective reactor components.

PHYSICAL CHARACTERISTICS

Redundant or defective components such as control rods; fuel element grabs, cables and General description:

> capsules; thermocouples and bob weights removed from stand pipe assemblies. The possibility of large items which may need special handling has not been fully assessed. Items may weigh up to about 1.5 t; sizes may be up to 5 m long and approximately 250

mm diameter.

Control rods, thermocouples, standpipe components, fuel element grabs, cables and Physical components (%vol):

Sealed sources: The waste does not contain sealed sources.

Bulk density (t/m3):

Comment on density: The assumption of 1 t/m3 as the average bulk density may be subject to revision.

CHEMICAL COMPOSITION

General description and

components (%wt):

Irradiated components removed from the reactor. The material is principally steel (mild steel, stainless steel, boron steel). Presence of other minor components is not assessed.

Chemical state: Neutral

Chemical form of

H-3: The tritium is likely to be incorporated into the steel.

radionuclides:

C-14: Carbon 14 is principally incorporated in steel. There may also be some graphite

contamination.

CI-36: The chemical form of chlorine 36 has not been determined.

U: The chemical form of uranium isotopes has not been determined but may be uranium oxides.

Pu: The chemical form of plutonium isotopes has not been determined but may be

plutonium oxides.

Metals and alloys (%wt): Metal thicknesses have not been fully assessed but bulk metal items may be present.

> (%wt) Type(s) / Grade(s) with proportions % of total C14 activity

Stainless steel..... ~45.0

Other ferrous metals......~45.0

Iron.....

Aluminium...... 0

Beryllium...... 0

Cobalt.....

Copper...... 0

Lead...... 0

WASTE STREAM 9C35 Miscellaneous Activated Components

	Magnox/Magnesium	0		
	Nickel	NE	Chromium and nickel will be present as alloys.	
	Titanium			
	Uranium			
	Zinc	0		
	Zircaloy/Zirconium	0		
	Other metals	~10.0	Not analysed.	
Organics	(%wt): No organic materia	al expected	l.	
		(%wt)	Type(s) and comment	% of total C14
	Total cellulosics	0		activity
	Paper, cotton	0		
	Wood	0		
	Halogenated plastics	0	Halogenated plastics are not expected but may possibly be present in small quantities.	
	Total non-halogenated plastics	0		
	Condensation polymers	0		
	Others	0		
	Organic ion exchange materials	0		
	Total rubber	0		
	Halogenated rubber	0	Halogenated rubbers are not expected but may possibly be present in small quantities.	
	Non-halogenated rubber	0		
	Hydrocarbons			
	Oil or grease			
	Fuel			
	Asphalt/Tarmac (cont.coal tar)			
	Asphalt/Tarmac (no coal tar)			
	Bitumen			
	Others			
	Other organics	0		
Other ma	terials (%wt): Traces of graphite	may be pre	esent.	
		(%wt)	Type(s) and comment	% of total C14 activity
	Inorganic ion exchange materials	0		
	Inorganic sludges and flocs	0		
	Soil	0		
	Brick/Stone/Rubble	0		
	Cementitious material	0		
	Sand			
	Glass/Ceramics	0		
	Graphite	TR		
	Desiccants/Catalysts			

WASTE STREAM 9C35 Miscellaneous Activated Components

Asbestos	0	
Non/low friable		
Moderately friable		
Highly friable		
Free aqueous liquids	0	
Free non-aqueous liquids	0	
Powder/Ash	TR	
Inorganic anions (%wt): Not fully assessed,	possibly tr	race quantities.
	(%wt)	Type(s) and comment
Fluoride	NE	
Chloride	NE	
lodide	NE	
Cyanide	0	
Carbonate	NE	
Nitrate	NE	
Nitrite	NE	
Phosphate	NE	
Sulphate	NE	
Sulphide	NE	
waste acceptance criteria: radiological hazard	(%wt)	Type(s) and comment
Combustible metals	0	
Low flash point liquids	0	
Explosive materials	0	
Phosphorus	0	
Hydrides	0	
Biological etc. materials	0	
Biodegradable materials		
Putrescible wastes	0	
Non-putrescible wastes		
Corrosive materials	0	
Pyrophoric materials	0	
Generating toxic gases	0	
Reacting with water	0	
Higher activity particles		
Soluble solids as bulk chemical compounds		
Hazardous substances / - non hazardous pollutants:		
	(%wt)	Type(s) and comment
Acrylamide		

WASTE STREAM 9C35 **Miscellaneous Activated Components**

Benzene				
Chlorinated solvent	S			
Formaldehyde				
Organometallics				
Phenol				
Styrene				
Tri-butyl phosphate				
Other organophosp	hates			
Vinyl chloride				
Arsenic				
Barium				
Boron				
Boron (in Boral)				
Boron (non-Boral)			
Cadmium				
Caesium				
Selenium				
Chromium				
Molybdenum				
Thallium				
Tin				
Vanadium				
Mercury compound	S			
Others				
Electronic Electrica	al Equipment (EEE)			
EEE Type 1				
EEE Type 2				
EEE Type 3				
EEE Type 4				
EEE Type 5				
Complexing agents (%wt):	No			
		(%wt)	Type(s) and comment	
EDTA				
DPTA				
NTA				
Polycarboxylic acid	s			
Other organic comp	olexants			
Total complexing ag	gents	0		
)/"substantial" thicknessess items assumed DIs.	s items considered

PACKAGING AND CONDITIONING

Conditioning method: The waste will be packaged into 4m boxes (with no shielding) and encapsulated.

Plant Name: None **WASTE STREAM** 9C35 **Miscellaneous Activated Components**

Location: **Dungeness A Site**

Plant startup date: 2092 Total capacity ~5000.0

(m³/y incoming waste):

Target start date for packaging this stream: 2092

Throughput for this stream (m³/y incoming waste):

~1.0

Other information:

The waste will be placed in baskets and then in the 4m box to be grouted.

Likely container

type:

Container	Waste packaged (%vol)	Waste loading (m³)	Payload (m³)	Number of packages
4m box (no shielding)	100.0	16.2	18.9	< 1

Likely container type

comment:

Range in container waste

volume:

Not yet determined.

Other information on

containers:

The container material is expected to be stainless steel.

Likely conditioning matrix:

BFS/OPC and PFA/OPC

Other information:

It is not yet know which grouting mix will be used when this waste is processed.

Conditioned density (t/m³):

Conditioned density

comment:

The density assumes conditioning with a cement based grout.

Other information on

conditioning:

The waste will be placed in baskets then packaged into 4m boxes (with no shielding) and

encapsulated.Baskets of other SPD3 ILW waste may be in the same package.

Opportunities for alternative

disposal routing:

Baseline Opportunity Management Route Management Route	Stream Date the volume (%)	nat Opportunity Inity Confidence	Comment
--	----------------------------	----------------------------------	---------

RADIOACTIVITY

Source: Irradiated components removed from the reactor. Control rods are likely to be components

of high activity.

Uncertainty: Specific activity is a function of Station operating history. The values quoted are indicative

of the activities expected.

Definition of total alpha and total beta/gamma:

Where totals are shown on the table of radionuclide activities they are the sums of the listed alpha or beta/gamma emitting radionuclides plus 'other alpha' or 'other beta/gamma'.

Measurement of radioactivities:

Estimates are based upon theoretical assessments.

Other information:

WASTE STREAM 9C35 Miscellaneous Activated Components

Muclicide		Mean radioactivity, TBq/m³			Mean radioactivity, TBq/m³					
H3	Nuclide	Waste at	Bands and	Future		Nuclide		Bands and	Future	
Be 10	H 3			-		Gd 153		8	İ	
Na 22										
ALZE	C 14	2.00E-02	CD 2			Ho 166m		8		
C136	Na 22		8			Tm 170		8		
Ar 39	Al 26		8			Tm 171		8		
Art Art B	CI 36	3E-05	CC 2			Lu 174		8		
K-40										
Ca 41										
Mn 53										
Mn 54										
Fe 55		4.475.07								
Co 60										
Ni 59										
Ni 63										
Zn 65										
Se 79		3.51E+00								
Kr 81										
Kr 86										
Rtb 87										
Sr 90										
Nb 91	Sr 90	<4.19E-05	D 3					8		
Nb 92	Zr 93		8			Th 228		8		
Nb 93m	Nb 91		8			Th 229		8		
Nb 94	Nb 92		8			Th 230		8		
Mo 93	Nb 93m		8							
TC 97 TC 99 TC 90		4E-05					7E-09			
TC 99										
Ru 106		45.00								
Pd 107		<1E-08								
Ag 108m 3.90E-05 CD 2 U 236 8 Ag 110m 8 U 236 8 Cd 109 8 U 238 <7E-09							-6 12E 00			
Ag 110m 8 U 236 8 Cd 109 8 U 238 <7E-09		3 90F-05					<0.12L-09			
Cd 109 8 U 238 <7E-09	_	3.90L-03								
Cd 113m 8 Np 237 8 Sn 119m 8 Pu 236 8 Sn 121m 8 Pu 238 <2.66E-06	_						<7E-09			
Sn 119m										
Sn 123 8 Pu 239 <3E-06										
Sn 126 8 Pu 240 <4.00E-06	Sn 121m		8			Pu 238	<2.66E-06	D 3		
Sb 125 8 Sb 126 8 Te 125m 8 Te 127m 8 I 129 8 Cs 134 <1.44E-08	Sn 123		8			Pu 239	<3E-06	D 3		
Sb 126 8 Pu 242 <2E-09	Sn 126		8			Pu 240	<4.00E-06	D 3		
Te 125m 8 Am 241 <1.12E-05			8							
Te 127m 8 Am 242m <1.85E-08										
1129										
Cs 134 <1.44E-08										
Cs 135 8 Cm 243 <4.25E-09		.4.445.00								
Cs 137 <1.41E-04		<1.44E-08								
Ba 133 8 La 137 8 La 138 8 Ce 144 8 Pm 145 8 Pm 147 <1.02E-07		~1 41E-04								
La 137 8 La 138 8 Ce 144 8 Pm 145 8 Pm 147 <1.02E-07		\1. 4 1L-04					\J.U3L-00			
La 138 8 Ce 144 8 Pm 145 8 Pm 147 <1.02E-07										
Ce 144 8 Cf 249 8 Pm 145 8 Cf 250 8 Pm 147 <1.02E-07										
Pm 145 8 Pm 147 <1.02E-07										
Pm 147 <1.02E-07										
Sm 151 <8.01E-07		<1.02E-07	D 3					8		
Eu 152 9.26E-06 C D 2 Eu 154 6.05E-06 C D 2 Total a <2.09E-05	Sm 147		8			Cf 252		8		
Eu 154 6.05E-06 CD 2 Total a <2.09E-05 D 3 0		<8.01E-07	D 3							
						_				
Eu 155 Total b/g 8.52E+00 C D 3 0		6.05E-06								
	Eu 155	1	8			Total b/g	8.52E+00	CD 3	0	

Bands (Upper and Lower)

A a factor of 1.5 B a factor of 3 C a factor of 10 D a factor of 100

D a factor of 100 E a factor of 1000

Note: Bands quantify uncertainty in mean radioactivity.

Code

- 1 Measured activity
- 2 Derived activity (best estimate)
- 3 Derived activity (upper limit)
- 4 Not present
- 5 Present but not significant
- 6 Likely to be present but not assessed
- 7 Present in significant quantities but not determined 8 Not expected to be present in significant quantity