

SITE	Dungeness A		
SITE OWNER	Nuclear Decommissioning Authority		
WASTE CUSTODIAN	Magnox Limited		
WASTE TYPE	ILW		
Is the waste subject to Scottish Policy:	No		
WASTE VOLUMES	Reported		
Stocks:	At 1.4.2022.....	0.4 m ³	
Total future arisings:		0 m ³	
Total waste volume:		0.4 m ³	
Comment on volumes:	The volume of each post filter is 0.053 m ³ and volume is based on 8 filters in stock. The station ceased generation on 31/12/2006.		
Uncertainty factors on volumes:	Stock (upper): x 1.2 Stock (lower): x 0.8	Arisings (upper) x Arisings (lower) x	
WASTE SOURCE	Spent post-filters from the fuel pond caesium removal unit.		
PHYSICAL CHARACTERISTICS			
General description:	Spent post filters that form part of the submersible caesium removal unit.		
Physical components (%wt):	Post filters (100%). The waste is spent post filters, which are composed principally of stainless steel supports with glass fibre/polyester filter elements and some organic materials. Post filters will typically hold a maximum of 20g of IONSIV material. Stainless steel (~100%), IONSIV material (<1%) and EPDM seal material (<1%). (EPDM is ethylene diene terpolymer).		
Sealed sources:	The waste does not contain sealed sources.		
Bulk density (t/m ³):	~0.53		
Comment on density:	The density of 0.53 t/m ³ assumes that each post filter will contain 20g of IONSIV material, giving a total mass of 28.1kg for each post filter.		
CHEMICAL COMPOSITION			
General description and components (%wt):	Post filters will typically hold IONSIV material (<1%) and EPDM seal material (<1%). (EPDM is ethylene diene terpolymer).		
Chemical state:	Neutral		
Chemical form of radionuclides:	H-3: Any tritium is likely to be present as water. Cl-36: The chlorine 36 content is insignificant. Pu: The chemical form of plutonium isotopes may be plutonium oxides.		
Metals and alloys (%wt):	-		
	(%wt)	Type(s) / Grade(s) with proportions	% of total C14 activity
Stainless steel.....	~98.0	The stainless steel is SS316L; nickel and chromium will be major constituents of the stainless steel post filter construction material.	
Other ferrous metals.....	NE		
Iron.....			
Aluminium.....	NE		
Beryllium.....	TR		
Cobalt.....			
Copper.....	NE		
Lead.....	NE		

WASTE STREAM

9C40

Ion Siv Unit Post Filters

Magnox/Magnesium.....	NE
Nickel.....	
Titanium.....	
Uranium.....	
Zinc.....	NE
Zircaloy/Zirconium.....	NE
Other metals.....	NE Only the stainless steel content of the waste has been assessed.

Organics (%wt): EPDM seal material (<1%wt) is also present. Halogenated plastics and rubbers are not expected in the waste.

	(%wt)	Type(s) and comment	% of total C14 activity
Total cellulosics.....	0		
Paper, cotton.....	0		
Wood.....	0		
Halogenated plastics	0		
Total non-halogenated plastics....	0		
Condensation polymers.....	0		
Others.....	0		
Organic ion exchange materials....	0		
Total rubber.....	<1.0	EPDM seal material	
Halogenated rubber	0		
Non-halogenated rubber.....	<1.0	EPDM seal material	
Hydrocarbons.....			
Oil or grease			
Fuel.....			
Asphalt/Tarmac (cont.coal tar)...			
Asphalt/Tarmac (no coal tar)....			
Bitumen.....			
Others.....			
Other organics.....	NE		

Other materials (%wt): -

	(%wt)	Type(s) and comment	% of total C14 activity
Inorganic ion exchange materials..	<1.0		
Inorganic sludges and flocs.....	0		
Soil.....	0		
Brick/Stone/Rubble.....	0		
Cementitious material.....	0		
Sand.....			
Glass/Ceramics.....	0		
Graphite.....	0		
Desiccants/Catalysts.....			
Asbestos.....	0		

WASTE STREAM**9C40****Ion Siv Unit Post Filters**

Non/low friable.....	
Moderately friable.....	
Highly friable.....	
Free aqueous liquids.....	TR
Free non-aqueous liquids.....	0
Powder/Ash.....	0

Inorganic anions (%wt): The inorganic anion content of the waste has not been assessed.

	(%wt)	Type(s) and comment
Fluoride.....		NE
Chloride.....		NE
Iodide.....		NE
Cyanide.....		NE
Carbonate.....		NE
Nitrate.....		NE
Nitrite.....		NE
Phosphate.....		NE
Sulphate.....		NE
Sulphide.....		NE

Materials of interest for waste acceptance criteria: There are no hazardous materials present in the waste. Free water may be associated with the retained IONSIV material.

	(%wt)	Type(s) and comment
Combustible metals.....	0	
Low flash point liquids.....	0	
Explosive materials.....	0	
Phosphorus.....	0	
Hydrides.....	0	
Biological etc. materials.....	0	
Biodegradable materials.....	0	
Putrescible wastes.....	0	
Non-putrescible wastes.....		
Corrosive materials.....	0	
Pyrophoric materials.....	0	
Generating toxic gases.....	0	
Reacting with water.....	0	
Higher activity particles.....		
Soluble solids as bulk chemical compounds.....		

Hazardous substances / non hazardous pollutants: none expected

	(%wt)	Type(s) and comment
Acrylamide.....		
Benzene.....		

WASTE STREAM 9C40 Ion Siv Unit Post Filters

Chlorinated solvents.....
Formaldehyde.....
Organometallics.....
Phenol.....
Styrene.....
Tri-butyl phosphate.....
Other organophosphates.....
Vinyl chloride.....
Arsenic.....
Barium.....
Boron..... 0
 Boron (in Boral).....
 Boron (non-Boral).....
Cadmium.....
Caesium.....
Selenium.....
Chromium.....
Molybdenum.....
Thallium.....
Tin.....
Vanadium.....
Mercury compounds.....
Others.....
Electronic Electrical Equipment (EEE)
 EEE Type 1.....
 EEE Type 2.....
 EEE Type 3.....
 EEE Type 4.....
 EEE Type 5.....

Complexing agents (%wt):

	(%wt)	Type(s) and comment
EDTA.....		
DPTA.....		
NTA.....		
Polycarboxylic acids.....		
Other organic complexants.....		
Total complexing agents.....		

Potential for the waste to . Stainless Steel so DI by definition
contain discrete items:**PACKAGING AND CONDITIONING**

Conditioning method: Initially the filters will be held in shielded drums in a buffer store, then transferred into a drum, crushed and the pucks placed into a DCIC

Plant Name: -

WASTE STREAM**9C40****Ion Siv Unit Post Filters**

Location: Dungeness A Site

Plant startup date: -

Total capacity
(m³/y incoming waste): -Target start date for
packaging this stream: -Throughput for this stream
(m³/y incoming waste): -

Other information: -

Likely container type:	Container	Waste packaged (%vol)	Waste loading (m ³)	Payload (m ³)	Number of packages
	3m ³ RS box	100.0	0.42	2.5	1

Likely container type
comment: -Range in container waste
volume: -Other information on
containers: -

Likely conditioning matrix:

Other information: -

Conditioned density (t/m³): -Conditioned density
comment: -Other information on
conditioning: -Opportunities for alternative
disposal routing: -

Baseline Management Route	Opportunity Management Route	Stream volume (%)	Estimated Date that Opportunity will be realised	Opportunity Confidence	Comment
-	-	-	-	-	-

RADIOACTIVITY

Source: Spent post filters from the submersible caesium removal unit, used for the removal of caesium isotopes from cooling pond water. Contamination by fission products, actinides and activation products.

Uncertainty: Specific activity is a function of Station operating history. The values quoted are indicative of the activities that might be expected.

Definition of total alpha and total beta/gamma: Where totals are shown on the table of radionuclide activities they are the sums of the listed alpha or beta/gamma emitting radionuclides plus 'other alpha' or 'other beta/gamma'.

Measurement of
radioactivities: Assuming ~20g of IonSiv per filter.

Other information: -

WASTE STREAM

9C40

Ion Siv Unit Post Filters

Nuclide	Mean radioactivity, TBq/m³				Nuclide	Mean radioactivity, TBq/m³			
	Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code		Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code
H 3		8			Gd 153		8		
Be 10		8			Ho 163		8		
C 14		8			Ho 166m		8		
Na 22		8			Tm 170		8		
Al 26		8			Tm 171		8		
Cl 36		8			Lu 174		8		
Ar 39		8			Lu 176		8		
Ar 42		8			Hf 178n		8		
K 40		8			Hf 182		8		
Ca 41		8			Pt 193		8		
Mn 53		8			Tl 204		8		
Mn 54		8			Pb 205		8		
Fe 55		8			Pb 210		8		
Co 60		8			Bi 208		8		
Ni 59		8			Bi 210m		8		
Ni 63	1.82E-09	CC 2			Po 210		8		
Zn 65		8			Ra 223		8		
Se 79		8			Ra 225		8		
Kr 81		8			Ra 226		8		
Kr 85		8			Ra 228		8		
Rb 87		8			Ac 227		8		
Sr 90	6.71E-01	CC 2			Th 227		8		
Zr 93		8			Th 228		8		
Nb 91		8			Th 229		8		
Nb 92		8			Th 230		8		
Nb 93m		8			Th 232		8		
Nb 94		8			Th 234		8		
Mo 93		8			Pa 231		8		
Tc 97		8			Pa 233		8		
Tc 99		8			U 232		8		
Ru 106		8			U 233		8		
Pd 107		8			U 234		8		
Ag 108m		8			U 235		8		
Ag 110m		8			U 236		8		
Cd 109		8			U 238		8		
Cd 113m		8			Np 237		8		
Sn 119m		8			Pu 236		8		
Sn 121m		8			Pu 238		8		
Sn 123		8			Pu 239	2E-09	CC 2		
Sn 126		8			Pu 240	2.00E-09	CC 2		
Sb 125		8			Pu 241	3.32E-08	CC 2		
Sb 126		8			Pu 242		8		
Te 125m		8			Am 241		8		
Te 127m		8			Am 242m		8		
I 129		8			Am 243		8		
Cs 134	7.11E-02	CC 2			Cm 242		8		
Cs 135		8			Cm 243		8		
Cs 137	6.80E+00	CC 2			Cm 244		8		
Ba 133		8			Cm 245		8		
La 137		8			Cm 246		8		
La 138		8			Cm 248		8		
Ce 144		8			Cf 249		8		
Pm 145		8			Cf 250		8		
Pm 147	2.39E-09	CC 2			Cf 251		8		
Sm 147		8			Cf 252		8		
Sm 151		8			Other a				
Eu 152		8			Other b/g				
Eu 154		8			Total a	4.00E-09	CC 2	0	
Eu 155		8			Total b/g	7.54E+00	CC 2	0	

Bands (Upper and Lower)

A a factor of 1.5

B a factor of 3

C a factor of 10

D a factor of 100

E a factor of 1000

Note: Bands quantify uncertainty in mean radioactivity.

Code

1 Measured activity

2 Derived activity (best estimate)

3 Derived activity (upper limit)

4 Not present

5 Present but not significant

6 Likely to be present but not assessed

7 Present in significant quantities but not determined

8 Not expected to be present in significant quantity