

WASTE STREAM**9F27****Miscellaneous Activated Components - R2****SITE** Sizewell A**SITE OWNER** Nuclear Decommissioning Authority**WASTE CUSTODIAN** Magnox Limited**WASTE TYPE** ILW; SPD3

Is the waste subject to Scottish Policy: No

WASTE VOLUMES

		Reported
Stocks:	At 1.4.2022.....	113.0m ³
Total future arisings:		0 m ³
Total waste volume:		113.0m ³
Comment on volumes:	-	
Uncertainty factors on volumes:	Stock (upper): x 1.2	Arisings (upper) x
	Stock (lower): x 0.8	Arisings (lower) x

WASTE SOURCE Redundant or defective components removed from the reactor cores or fuelling machines / servicing machines.**PHYSICAL CHARACTERISTICS**

General description: Flux flattening elements (absorber bars), fuel element support struts, fuelling machine broken hoses, flux scanning wires, control rods and chains, thermocouple harnesses and cables, charge chute bottom sections and BCD equipment. Special handling will be required. Control rods and charge chute lengths may be of the order of 6 m long, assuming they have not been cut into sections. Components may weigh up to 0.2 t. Special handling will be required.

Physical components (%vol): Control rods (1% vol), absorber bars (10% vol), thermocouples (1% vol), charge chutes (87% vol) and BCD equipment (1% vol).

Sealed sources: The waste does not contain sealed sources.

Bulk density (t/m³): <1

Comment on density: The average density has not been fully assessed but will be less than 1 t/m³.

CHEMICAL COMPOSITION

General description and components (%wt): Principally mild steel with other wastes containing graphite and stainless steel. Other components that may be present in smaller quantities are copper, boron steel, electrical wire insulation and polythene sheeting used for wrapping contaminated items.

Chemical state: Neutral

Chemical form of radionuclides: H-3: The chemical form of tritium has not been determined.
C-14: The chemical form of carbon 14 may be graphite.
Cl-36: The chemical form of chlorine 36 has not been determined.
Se-79: The selenium content is insignificant.
Tc-99: The technetium content is insignificant.
Ra: The radium isotope content is insignificant.
Th: The thorium isotope content is insignificant.
U: The uranium isotope content is insignificant.
Np: The neptunium content is insignificant.
Pu: The chemical form of plutonium isotopes has not been determined but may be in the form of plutonium oxides.

Metals and alloys (%wt): 99% of the waste is bulk metal items.

	(%wt)	Type(s) / Grade(s) with proportions	% of total C14 activity
Stainless steel.....	~7.5	Nickel and chromium will be present as constituents of stainless steel.	
Other ferrous metals.....	~90.0	Generally carbon steels with 300 series stainless steels.	
Iron.....			

WASTE STREAM

9F27

Miscellaneous Activated Components - R2

Aluminium.....	0
Beryllium.....	0
Cobalt.....	
Copper.....	<0.10
Lead.....	0
Magnox/Magnesium.....	TR
Nickel.....	
Titanium.....	
Uranium.....	
Zinc.....	0
Zircaloy/Zirconium.....	0
Other metals.....	NE

Cadmium may be present as an additive in the steel of the control rods.

Organics (%wt): Trace amounts of oil may exist. There are no halogenated plastics or rubbers present.

	(%wt)	Type(s) and comment	% of total C14 activity
Total cellulose.....	0		
Paper, cotton.....	0		
Wood.....	0		
Halogenated plastics	0		
Total non-halogenated plastics.....	0		
Condensation polymers.....	0		
Others.....	0		
Organic ion exchange materials....	0		
Total rubber.....	0		
Halogenated rubber	0		
Non-halogenated rubber.....	0		
Hydrocarbons.....			
Oil or grease			
Fuel.....			
Asphalt/Tarmac (cont.coal tar)...			
Asphalt/Tarmac (no coal tar)....			
Bitumen.....			
Others.....			
Other organics.....	TR		

Other materials (%wt): Graphite may be present in trace quantities.

	(%wt)	Type(s) and comment	% of total C14 activity
Inorganic ion exchange materials..	0		
Inorganic sludges and flocs.....	0		
Soil.....	0		
Brick/Stone/Rubble.....	0		
Cementitious material.....	0		

WASTE STREAM

9F27

Miscellaneous Activated Components - R2

Sand.....	
Glass/Ceramics.....	0
Graphite.....	TR
Desiccants/Catalysts.....	
Asbestos.....	0
Non/low friable.....	
Moderately friable.....	
Highly friable.....	
Free aqueous liquids.....	0
Free non-aqueous liquids.....	TR
Powder/Ash.....	0

Inorganic anions (%wt): Not fully assessed.

	(%wt)	Type(s) and comment
Fluoride.....	NE	
Chloride.....	NE	
Iodide.....	NE	
Cyanide.....	0	
Carbonate.....	NE	
Nitrate.....	NE	
Nitrite.....	NE	
Phosphate.....	NE	
Sulphate.....	NE	
Sulphide.....	NE	

Materials of interest for waste acceptance criteria: -

	(%wt)	Type(s) and comment
Combustible metals.....	TR	
Low flash point liquids.....	0	
Explosive materials.....	0	
Phosphorus.....	0	
Hydrides.....	0	
Biological etc. materials.....	0	
Biodegradable materials.....		
Putrescible wastes.....	0	
Non-putrescible wastes.....		
Corrosive materials.....	0	
Pyrophoric materials.....	0	
Generating toxic gases.....	0	
Reacting with water.....	TR	
Higher activity particles.....		
Soluble solids as bulk chemical compounds.....		

WASTE STREAM**9F27****Miscellaneous Activated Components - R2**Hazardous substances /
non hazardous pollutants:

Cadmium may be present as an additive in the steel of the control rods.

(%wt) Type(s) and comment

Acrylamide.....

Benzene.....

Chlorinated solvents.....

Formaldehyde.....

Organometallics.....

Phenol.....

Styrene.....

Tri-butyl phosphate.....

Other organophosphates.....

Vinyl chloride.....

Arsenic.....

Barium.....

Boron.....

Boron (in Boral).....

Boron (non-Boral).....

Cadmium.....

Caesium.....

Selenium.....

Chromium.....

Molybdenum.....

Thallium.....

Tin.....

Vanadium.....

Mercury compounds.....

Others.....

Electronic Electrical Equipment (EEE)

EEE Type 1.....

EEE Type 2.....

EEE Type 3.....

EEE Type 4.....

EEE Type 5.....

Complexing agents (%wt): No

(%wt) Type(s) and comment

EDTA.....

DPTA.....

NTA.....

Polycarboxylic acids.....

Other organic complexants.....

Total complexing agents..... 0

WASTE STREAM**9F27****Miscellaneous Activated Components - R2**

Potential for the waste to contain discrete items: Yes. Large Metal Items (LMIs)/"substantial" thickness items considered "durable" assumed DIs; Stainless items assumed DIs.

PACKAGING AND CONDITIONING

Conditioning method: The waste will be conditioned to satisfy the disposal requirements which are effective at the time of retrieval/conditioning. It is currently assumed that the waste will be placed in baskets in the waste packages and will be encapsulated but not supercompacted.

Plant Name: None

Location: Sizewell A Decommissioning Site

Plant startup date: 2092

Total capacity (m³/y incoming waste): ~5000.0

Target start date for packaging this stream: 2092

Throughput for this stream (m³/y incoming waste): ~50.0

Other information: All of the waste is expected to be retrieved and conditioned when a conditioning campaign is undertaken.

Likely container type:	Container	Waste packaged (%vol)	Waste loading (m ³)	Payload (m ³)	Number of packages
	4m box (no shielding)	100.0	16.2	18.9	7

Likely container type comment: It is now assumed that the waste will be placed in baskets in the waste packages and will be encapsulated but not supercompacted. BFS/OPC (possibly PFA/OPC) is the likely encapsulation matrix.

Range in container waste volume: Not yet determined. No significant variability is expected.

Other information on containers: The container material is expected to be stainless steel. The type of container to be used is under review.

Likely conditioning matrix: BFS/OPC (possibly PFA/OPC) is the likely encapsulation matrix.

Other information: Conditioned density (t/m³): ~3.0

Conditioned density comment: -

Other information on conditioning: Waste will be retained on site pending Final Decommissioning and Site Clearance. Appropriate plant to be provided at the Station in accordance with Company strategy. The waste will be in baskets placed in the waste packages. Baskets of different Final Decommissioning ILW wastes may be in the same waste package. The encapsulation matrix is likely to be BFS/OPC and the density of the conditioned waste product would be about 3 t/m³.

Opportunities for alternative disposal routing: -

Baseline Management Route	Opportunity Management Route	Stream volume (%)	Estimated Date that Opportunity will be realised	Opportunity Confidence	Comment
-	-	-	-	-	-

RADIOACTIVITY

Source: Redundant or defective components such as control rods, charge chutes, absorber bars

WASTE STREAM**9F27****Miscellaneous Activated Components - R2**

	and thermocouples removed from reactor cores and fuelling machines/reactor servicing machine.
Uncertainty:	Activity estimates are thought to be accurate to within a factor of 10, but could be lower by a factor of 100.
Definition of total alpha and total beta/gamma:	Where totals are shown on the table of radionuclide activities they are the sums of the listed alpha or beta/gamma emitting radionuclides plus 'other alpha' or 'other beta/gamma'.
Measurement of radioactivities:	Activities have been calculated from activation calculations with assumptions for contamination.
Other information:	Specific activity is a function of Station operating history. The values quoted are indicative of the activities that might be expected.

WASTE STREAM

9F27

Miscellaneous Activated Components - R2

Nuclide	Mean radioactivity, TBq/m ³				Nuclide	Mean radioactivity, TBq/m ³			
	Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code		Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code
H 3	8.71E-03	CD 2			Gd 153		8		
Be 10		8			Ho 163		8		
C 14	2.00E-03	CD 2			Ho 166m		8		
Na 22		8			Tm 170		8		
Al 26		8			Tm 171		8		
Cl 36	3E-05	CC 2			Lu 174		8		
Ar 39		8			Lu 176		8		
Ar 42		8			Hf 178n		8		
K 40		8			Hf 182		8		
Ca 41		8			Pt 193		8		
Mn 53		8			Tl 204		8		
Mn 54	1.07E-09	CD 2			Pb 205		8		
Fe 55	9.93E-04	CD 2			Pb 210		8		
Co 60	1.45E-03	CD 2			Bi 208		8		
Ni 59		8			Bi 210m		8		
Ni 63		8			Po 210		8		
Zn 65		8			Ra 223		8		
Se 79		8			Ra 225		8		
Kr 81		8			Ra 226		8		
Kr 85		8			Ra 228		8		
Rb 87		8			Ac 227		8		
Sr 90	4.90E-05	CD 2			Th 227		8		
Zr 93		8			Th 228		8		
Nb 91		8			Th 229		8		
Nb 92		8			Th 230		8		
Nb 93m		8			Th 232		8		
Nb 94		8			Th 234		8		
Mo 93		8			Pa 231		8		
Tc 97		8			Pa 233		8		
Tc 99		8			U 232		8		
Ru 106		8			U 233		8		
Pd 107		8			U 234		8		
Ag 108m		8			U 235		8		
Ag 110m		8			U 236		8		
Cd 109		8			U 238		8		
Cd 113m		8			Np 237		8		
Sn 119m		8			Pu 236		8		
Sn 121m		8			Pu 238	2.66E-06	CD 2		
Sn 123		8			Pu 239	3E-06	CD 2		
Sn 126		8			Pu 240	4.00E-06	CD 2		
Sb 125		8			Pu 241	3.92E-05	CD 2		
Sb 126		8			Pu 242		8		
Te 125m		8			Am 241	1.11E-05	CD 2		
Te 127m		8			Am 242m		8		
I 129		8			Am 243		8		
Cs 134		8			Cm 242		8		
Cs 135		8			Cm 243	2.13E-08	CD 2		
Cs 137	2.84E-04	CD 2			Cm 244	2.27E-07	CD 2		
Ba 133		8			Cm 245		8		
La 137		8			Cm 246		8		
La 138		8			Cm 248		8		
Ce 144		8			Cf 249		8		
Pm 145		8			Cf 250		8		
Pm 147		8			Cf 251		8		
Sm 147		8			Cf 252		8		
Sm 151		8			Other a				
Eu 152		8			Other b/g				
Eu 154		8			Total a	2.10E-05	CD 2	0	
Eu 155		8			Total b/g	1.35E-02	CD 2	0	

Bands (Upper and Lower)

- A a factor of 1.5
- B a factor of 3
- C a factor of 10
- D a factor of 100
- E a factor of 1000

Note: Bands quantify uncertainty in mean radioactivity.

Code

- 1 Measured activity
- 2 Derived activity (best estimate)
- 3 Derived activity (upper limit)
- 4 Not present
- 5 Present but not significant
- 6 Likely to be present but not assessed
- 7 Present in significant quantities but not determined
- 8 Not expected to be present in significant quantity