

WASTE STREAM	9G316	Graphite LLW
---------------------	--------------	---------------------

SITE Trawsfynydd
SITE OWNER Nuclear Decommissioning Authority

WASTE CUSTODIAN Magnox Limited

WASTE TYPE LLW

Is the waste subject to Scottish Policy: No

WASTE VOLUMES

		Reported
Stocks:	At 1.4.2022.....	0 m ³
Future arisings -	1.4.2074 - 31.3.2083.....	48.0 m ³
Total future arisings:		48.0 m ³
Total waste volume:		48.0 m ³

Comment on volumes: For inventory purposes the arisings are assumed to arise at a uniform rate over 9 years. Final Dismantling & Site Clearance is assumed to commence in 2074 with reactor dismantling commencing in 2074 and lasting for 9 years. The volumes and radioactivity have been calculated for 85 years after reactor shutdown, i.e. 2076.

Uncertainty factors on volumes: Stock (upper): x Arisings (upper) x 1.2
 Stock (lower): x Arisings (lower) x 0.8

WASTE SOURCE Reflector and thermal column graphite from reactor dismantling.

PHYSICAL CHARACTERISTICS

General description: Graphite blocks and other graphite components.

Physical components (%wt): Graphite (100%).

Sealed sources: The waste does not contain sealed sources.

Bulk density (t/m³): ~1.25

Comment on density: Density estimate based upon the assumed packing efficiency of the waste. The density is the effective density for packaging assuming 90% of the graphite is in blocks and 10% is rubble.

CHEMICAL COMPOSITION

General description and components (%wt): Graphite and possibly traces of ferrous metals.

Chemical state: Neutral

Chemical form of radionuclides: H-3: Tritium may be chemically bound with the graphite.
 C-14: Carbon 14 will be present as graphite.
 Cl-36: Chlorine 36 will probably be chemically bound to the graphite. Some may be linked chemically with impurities in the graphite.
 Se-79: The selenium content is insignificant.
 Tc-99: The technetium content is insignificant.
 Ra: Radium isotope content is insignificant.
 Th: The thorium content is insignificant.
 U: There may be traces of uranium as metal or oxide.
 Np: The neptunium content is insignificant.
 Pu: There may be traces of plutonium as metal or oxide.

Metals and alloys (%wt): There are no metallic items present.

	(%wt)	Type(s) / Grade(s) with proportions	% of total C14 activity
Stainless steel.....	TR	There may be trace contamination by ferrous metals.	
Other ferrous metals.....	TR	There may be trace contamination by ferrous metals.	
Iron.....			
Aluminium.....	0		

WASTE STREAM	9G316	Graphite LLW
---------------------	--------------	---------------------

Beryllium.....	TR	
Cobalt.....		
Copper.....	0	
Lead.....	0	
Magnox/Magnesium.....	0	
Nickel.....		
Titanium.....		
Uranium.....		
Zinc.....	0	
Zircaloy/Zirconium.....	0	
Other metals.....	0	There are no "other" metals.

Organics (%wt): None expected. No halogenated plastics or rubbers will be present.

	(%wt)	Type(s) and comment	% of total C14 activity
Total cellulosics.....	0		
Paper, cotton.....	0		
Wood.....	0		
Halogenated plastics	0		
Total non-halogenated plastics.....	0		
Condensation polymers.....	0		
Others.....	0		
Organic ion exchange materials....	0		
Total rubber.....	0		
Halogenated rubber	0		
Non-halogenated rubber.....	0		
Hydrocarbons.....			
Oil or grease			
Fuel.....			
Asphalt/Tarmac (cont.coal tar)...			
Asphalt/Tarmac (no coal tar)....			
Bitumen.....			
Others.....			
Other organics.....	0		

Other materials (%wt): -

	(%wt)	Type(s) and comment	% of total C14 activity
Inorganic ion exchange materials..	0		
Inorganic sludges and flocs.....	0		
Soil.....	0		
Brick/Stone/Rubble.....	0		
Cementitious material.....	0		
Sand.....			
Glass/Ceramics.....	0		

WASTE STREAM	9G316	Graphite LLW
---------------------	--------------	---------------------

Graphite.....	100.0	100.0
Desiccants/Catalysts.....		
Asbestos.....	0	
Non/low friable.....		
Moderately friable.....		
Highly friable.....		
Free aqueous liquids.....	0	
Free non-aqueous liquids.....	0	
Powder/Ash.....	0	

Inorganic anions (%wt): None of the inorganic anions listed in the table is expected to be present at greater than trace concentration.

	(%wt)	Type(s) and comment
Fluoride.....	TR	Detected at trace levels in inactive graphite material.
Chloride.....	TR	
Iodide.....	0	
Cyanide.....	0	
Carbonate.....	TR	
Nitrate.....	TR	
Nitrite.....	TR	
Phosphate.....	TR	Detected at trace levels in inactive graphite material.
Sulphate.....	TR	Detected at trace levels in inactive graphite material.
Sulphide.....	0	

Materials of interest for waste acceptance criteria: No materials likely to pose a fire or other non-radiological hazard have been identified. Graphite presents a low fire risk; it is difficult but not impossible to ignite.

	(%wt)	Type(s) and comment
Combustible metals.....	0	
Low flash point liquids.....	0	
Explosive materials.....	0	
Phosphorus.....	TR	Detected at trace levels in inactive graphite material.
Hydrides.....	0	
Biological etc. materials.....	0	
Biodegradable materials.....	0	
Putrescible wastes.....	0	
Non-putrescible wastes.....		
Corrosive materials.....	0	
Pyrophoric materials.....	0	
Generating toxic gases.....	0	
Reacting with water.....	0	
Higher activity particles.....		

WASTE STREAM 9G316 Graphite LLW

Soluble solids as bulk chemical compounds.....

Hazardous substances / None expected
non hazardous pollutants:

	(%wt)	Type(s) and comment
Acrylamide.....		
Benzene.....		
Chlorinated solvents.....		
Formaldehyde.....		
Organometallics.....		
Phenol.....		
Styrene.....		
Tri-butyl phosphate.....		
Other organophosphates.....		
Vinyl chloride.....		
Arsenic.....	TR	Detected at trace levels in inactive graphite material.
Barium.....		
Boron.....	0	
Boron (in Boral).....		
Boron (non-Boral).....		
Cadmium.....		
Caesium.....		
Selenium.....		
Chromium.....		
Molybdenum.....		
Thallium.....	TR	Detected at trace levels in inactive graphite material.
Tin.....		
Vanadium.....		
Mercury compounds.....		
Others.....	TR	Gallium, germanium and rubidium detected at trace levels in inactive graphite material.
Electronic Electrical Equipment (EEE)		
EEE Type 1.....		
EEE Type 2.....		
EEE Type 3.....		
EEE Type 4.....		
EEE Type 5.....		

Complexing agents (%wt): Yes

	(%wt)	Type(s) and comment
EDTA.....		
DPTA.....		
NTA.....		

WASTE STREAM 9G316 Graphite LLW

Polycarboxylic acids.....
 Other organic complexants.....
 Total complexing agents..... TR

Potential for the waste to contain discrete items: Yes. Graphite Bricks/Tiles assumed to be DIs; may also include some HDRIs (e.g. steel pins, Magnox Seals)

TREATMENT, PACKAGING AND DISPOSAL

Planned on-site / off-site treatment(s):

Treatment	On-site / Off site	Stream volume %
Low force compaction Supercompaction (HFC) Incineration Solidification Decontamination Metal treatment Size reduction Decay storage Recycling / reuse Other / various None		100.0

Comment on planned treatments:

The waste will be placed into baskets. Baskets of different Final Site Clearance LLW may be placed in the same package. The occupied volume in the package is greater than the original waste volume. A conditioning factor of 1.167 has been assumed to allow for the waste being placed in baskets before loading into standard 4m boxes. The waste will then be encapsulated.

Disposal Routes:

Disposal Route	Stream volume %	Disposal density t/m3
Expected to be consigned to the LLW Repository Expected to be consigned to a Landfill Facility Expected to be consigned to an On-Site Disposal Facility Expected to be consigned to an Incineration Facility Expected to be consigned to a Metal Treatment Facility Expected to be consigned as Out of Scope Expected to be recycled / reused Disposal route not known	100.0	1.3

Classification codes for waste expected to be consigned to a landfill facility: -

Upcoming (2022/23-2024/25) Waste Routing (if expected to change from above):

Disposal Route	Stream volume %		
	2022/23	2023/24	2024/25
Expected to be consigned to the LLW Repository Expected to be consigned to a Landfill Facility Expected to be consigned to an On-Site Disposal Facility Expected to be consigned to an Incineration Facility Expected to be consigned to a Metal Treatment Facility Expected to be consigned as Out of Scope Expected to be recycled / reused Disposal route not known			

Opportunities for alternative disposal routing: -

WASTE STREAM	9G316	Graphite LLW
---------------------	--------------	---------------------

Baseline Management Route	Opportunity Management Route	Stream volume (%)	Estimated Date that Opportunity will be realised	Opportunity Confidence	Comment
-	-	-	-	-	-

Waste Packaging for Disposal:

Container	Stream volume %	Waste loading m ³	Number of packages
1/3 Height IP-1 ISO			
2/3 Height IP-2 ISO			
1/2 Height WAMAC IP-2 ISO			
1/2 Height IP-2 Disposal/Re-usable ISO			
2m box (no shielding)			
4m box (no shielding)	100.0	16.2	3
Other			

Other information: Data have been presented as though the waste will be in dedicated containers. However it is likely that this waste will be placed in containers with other LLW. The type of container to be used is under review.

Waste Planned for Disposal at the LLW Repository:

Container voidage: The waste is expected to be grouted. In-accessible voidage is not expected.

Waste Characterisation Form (WCH): The waste meets the LLWR's Waste Acceptance Criteria (WAC). The waste does not have a current WCH.

Waste consigned for disposal to LLWR in year of generation: The timing of consignment of the waste for disposal cannot be determined at present.

Non-Containerised Waste for In-Vault Grouting: (Not applicable to this waste stream)

Stream volume (%): -

Waste stream variation: -

Bounding cuboidal volume:

Inaccessible voidage: -

Other information: -

RADIOACTIVITY

Source: Activation of the graphite and impurities.

Uncertainty: The values quoted were derived by calculation from available material specification and are indicative of the activities that are expected. The major source of uncertainty is the impurity levels.

Definition of total alpha and total beta/gamma: Where totals are shown on the table of radionuclide activities they are the sums of the listed alpha or beta/gamma emitting radionuclides plus 'other alpha' or 'other beta/gamma'.

Measurement of radioactivities: The specific activities were estimated from neutron activation calculations of the material and its impurities. With additional data from newly calculated inventories including 100 ppb U precursor as per M/EF/GEN/EAN/0008/20

Other information: The activities quoted are those at 85 years after reactor shutdown, i.e. in 2076. There may be some contamination by Cs137. Fission of uranium impurity in the graphite may result in some fission product and actinide activity.

WASTE STREAM 9G316 Graphite LLW

Nuclide	Mean radioactivity, TBq/m ³				Nuclide	Mean radioactivity, TBq/m ³			
	Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code		Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code
H 3			1.1E-04	CC 2	Gd 153				8
Be 10				8	Ho 163				8
C 14			1.4E-04	CC 2	Ho 166m		3.89E-09	CC	2
Na 22				8	Tm 170				8
Al 26				8	Tm 171				8
Cl 36			4.39E-07	CC 2	Lu 174				8
Ar 39				8	Lu 176				8
Ar 42				8	Hf 178n				8
K 40				8	Hf 182				8
Ca 41			3.69E-07	CC 2	Pt 193				8
Mn 53				8	Tl 204				8
Mn 54				8	Pb 205				8
Fe 55				8	Pb 210				8
Co 60				8	Bi 208				8
Ni 59			6.4E-08	CC 2	Bi 210m				8
Ni 63			3.85E-06	CC 2	Po 210				8
Zn 65				8	Ra 223				8
Se 79				8	Ra 225				8
Kr 81				8	Ra 226				8
Kr 85			6.63E-07	CC 2	Ra 228				8
Rb 87				8	Ac 227				8
Sr 90			1.64E-04	CC 2	Th 227				8
Zr 93			3.98E-08	CC 2	Th 228				8
Nb 91				8	Th 229				8
Nb 92				8	Th 230				8
Nb 93m			3.81E-08	CC 2	Th 232				8
Nb 94				8	Th 234		1.07E-09	CC	2
Mo 93				8	Pa 231				8
Tc 97				8	Pa 233		1.64E-09	CC	2
Tc 99			3.15E-07	CC 2	U 232				8
Ru 106				8	U 233				8
Pd 107			3.56E-09	CC 2	U 234		1.1E-08	CC	2
Ag 108m			2.52E-09	CC 2	U 235				8
Ag 110m				8	U 236				8
Cd 109				8	U 238		1.07E-09	CC	2
Cd 113m				8	Np 237		1.65E-09	CC	2
Sn 119m				8	Pu 236				8
Sn 121m			3.85E-07	CC 2	Pu 238		2.81E-05	CC	2
Sn 123				8	Pu 239		2.88E-06	CC	2
Sn 126			1.37E-08	CC 2	Pu 240		1.07E-05	CC	2
Sb 125				8	Pu 241		2.9E-05	CC	2
Sb 126			1.91E-09	CC 2	Pu 242		2.29E-07	CC	2
Te 125m				8	Am 241		5.54E-05	CC	2
Te 127m				8	Am 242m		7.75E-08	CC	2
I 129				8	Am 243		4.35E-06	CC	2
Cs 134				8	Cm 242		6.42E-08	CC	2
Cs 135			1.12E-08	CC 2	Cm 243		7.79E-08	CC	2
Cs 137			3.13E-04	CC 2	Cm 244		6.04E-05	CC	2
Ba 133			1.05E-09	CC 2	Cm 245		1.14E-07	CC	2
La 137				8	Cm 246		2.1E-07	CC	2
La 138				8	Cm 248				8
Ce 144				8	Cf 249				8
Pm 145				8	Cf 250				8
Pm 147				8	Cf 251				8
Sm 147				8	Cf 252				8
Sm 151			2.23E-06	CC 2	Other a				
Eu 152			5.66E-06	CC 2	Other b/g				
Eu 154			3.38E-07	CC 2	Total a	0	1.63E-04	CC	2
Eu 155				8	Total b/g	0	7.71E-04	CC	2

Bands (Upper and Lower)

- A a factor of 1.5
- B a factor of 3
- C a factor of 10
- D a factor of 100
- E a factor of 1000

Note: Bands quantify uncertainty in mean radioactivity.

Code

- 1 Measured activity
- 2 Derived activity (best estimate)
- 3 Derived activity (upper limit)
- 4 Not present
- 5 Present but not significant
- 6 Likely to be present but not assessed
- 7 Present in significant quantities but not determined
- 8 Not expected to be present in significant quantity