SITE Wylfa

SITE OWNER Nuclear Decommissioning Authority

WASTE CUSTODIAN Magnox Limited

WASTE TYPE ILW

Is the waste subject to

Scottish Policy:

No

WASTE VOLUMES

Total waste volume: 5915.0 m³

Comment on volumes: For inventory purposes the arisings are assumed to arise at a uniform rate over five years.

Final Dismantling & Site Clearance is assumed to commence in 2097 with reactor dismantling commencing in 2101 and lasting for 5 years. The volumes and radioactivity

have been calculated for 85 years after reactor shutdown, i.e. 2100

Uncertainty factors on Stock (upper): x Arisings (upper) x 1.2 volumes: Stock (lower): x Arisings (lower) x 0.8

WASTE SOURCE Moderator graphite from reactor dismantling.

PHYSICAL CHARACTERISTICS

General description: Graphite blocks and other graphite components. Waste can be packaged in standard ILW

packages.

Physical components (%wt): Graphite (~100%).

Sealed sources: The waste does not contain sealed sources.

Bulk density (t/m³): ~1.25

Comment on density: Density estimate based upon assumed packing efficiency of the waste. The density is the

effective density for packaging assuming 90% of the graphite is in blocks and 10% is

rubble.

CHEMICAL COMPOSITION

General description and components (%wt):

Graphite and possibly traces of ferrous metals.

Chemical state: Neutral

Chemical form of H-3: Tritium may be chemically bound with the graphite.

radionuclides: C-14: Carbon 14 will be present as graphite.

Cl-36: Chlorine 36 will probably be chemically bound to the graphite. Some may be linked

chemically with impurities in the graphite. Se-79: The selenium content is insignificant. Tc-99: The technetium content is insignificant. Ra: Radium isotope content is insignificant. Th: The thorium content is insignificant.

U: There may be traces of uranium as metal or oxide.

Np: The neptunium content is insignificant.

Pu: There may be traces of plutonium as metal or oxide.

Metals and alloys (%wt): There are no metallic items present.

(%wt) Type(s) / Grade(s) with proportions % of total C14 activity

Stainless steel...... TR There may be trace contamination

by ferrous metals.

Other ferrous metals...... TR There may be trace contamination

by ferrous metals.

	Beryllium	TR		
	Cobalt			
	Copper	0		
	Lead	0		
	Magnox/Magnesium	0		
	Nickel			
	Titanium			
	Uranium			
	Zinc	0		
	Zircaloy/Zirconium	. 0		
	Other metals	. 0	There are no "other" metals present.	
Organics	(%wt): None expected. Ha	alogenated	plastics and rubbers will not be present.	
		(%wt)	Type(s) and comment	% of total C14
	Total cellulosics	0		activity
	Paper, cotton	0		
	Wood	0		
	Halogenated plastics	0		
	Total non-halogenated plastics	0		
	Condensation polymers	0		
	Others	0		
	Organic ion exchange materials	0		
	Total rubber	0		
	Halogenated rubber	0		
	Non-halogenated rubber	0		
	Hydrocarbons			
	Oil or grease			
	Fuel			
	Asphalt/Tarmac (cont.coal tar)			
	Asphalt/Tarmac (no coal tar)			
	Bitumen			
	Others			
	Other organics	0		
Other ma	aterials (%wt):			
		(%wt)	Type(s) and comment	% of total C14
		(70Wt)	Type(3) and comment	activity
	Inorganic ion exchange materials	0		
	Inorganic sludges and flocs	0		
	Soil	0		
	Brick/Stone/Rubble	0		
	Cementitious material	0		
	Sand			
	Glass/Ceramics	0		

	Graphite		100.0		100.0
	•	ysts			
			0		
		le			
	Moderately fri	iable			
	•				
		uids	0		
	•	ıs liquids	0		
	•		0		
Inorgania ani				stad in the table is expected to be present at arr	ator than
Inorganic anic	ons (%wt).	trace concentration.	c amons iis	sted in the table is expected to be present at gre	eater man
			(%wt)	Type(s) and comment	
	Fluoride		TR	Detected at trace levels in inactive graphite material.	
	Chloride		TR		
	lodide		0		
	Cyanide		0		
	Carbonate		TR		
	Nitrate		TR		
	Nitrite		TR		
	Phosphate		TR	Detected at trace levels in inactive graphite material.	
	Sulphate		TR	Detected at trace levels in inactive graphite material.	
	Sulphide		0		
Materials of ir waste accept				e or other non-radiological hazard have been id c; it is difficult but not impossible to ignite.	entified.
			(%wt)	Type(s) and comment	
	Combustible met	als	0		
	Low flash point lie	quids	0		
	Explosive materia	als	0		
	Phosphorus		TR	Detected at trace levels in inactive graphite material.	
	Hydrides		0		
	Biological etc. ma	aterials	0		
Biodegradable materials		aterials			
	Putrescible was	stes	0		
	Non-putrescible	e wastes			
	Corrosive materia	als	0		
	Pyrophoric mater	rials	0		
	Generating toxic	gases	0		
	Reacting with wa	ter	0		
	Higher activity pa	articles			

Soluble solids as bulk chemical compounds		
Hazardous substances / None expected non hazardous pollutants:		
	(%wt)	Type(s) and comment
Acrylamide		
Benzene		
Chlorinated solvents		
Formaldehyde		
Organometallics		
Phenol		
Styrene		
Tri-butyl phosphate		
Other organophosphates		
Vinyl chloride		
Arsenic	TR	Detected at trace levels in inactive graphite material.
Barium		
Boron		
Boron (in Boral)		
Boron (non-Boral)		
Cadmium		
Caesium		
Selenium		
Chromium		
Molybdenum		
Thallium	TR	Detected at trace levels in inactive graphite material.
Tin		
Vanadium		
Mercury compounds		
Others	TR	Gallium, germanium and rubidium all detected at trace levels in inactive graphite material.
Electronic Electrical Equipment (EEE)		
EEE Type 1		
EEE Type 2		
EEE Type 3		
EEE Type 4		
EEE Type 5		
Complexing agents (%wt): Yes		
	(%wt)	Type(s) and comment
EDTA		
DPTA		
NTA		

Polycarboxylic acids.....

Other organic complexants......

Total complexing agents..... TR

Potential for the waste to contain discrete items:

Yes. Graphite Bricks/Tiles assumed to be Dls. Bricks assumed drummed (ungrouted) so assumed Bricks are DIs; If grouted, Drum is also a DI. "Rubble" pieces assumed drummed (ungrouted) assumed NOT DIs; If grouted, Drum is a DI.

PACKAGING AND CONDITIONING

The waste is not expected to be supercompacted. The treatment envisaged is the Conditioning method:

placement of the waste in baskets followed by encapsulation.

Plant Name: None

Location: Wylfa Power Station

Plant startup date: 2101 Total capacity ~5000.0

(m³/y incoming waste):

Target start date for packaging this stream: 2101

Throughput for this stream (m³/y incoming waste):

915.5

Other information: The processing strategy has not yet been determined.

Likely container

type:

r	Container	Waste packaged (%vol)	Waste loading (m³)	Payload (m³)	Number of packages
2	1m box (no shielding)	100.0	16.2	18.9	366

Likely container type

comment:

The container choice may be influenced by the Transport Regulations at the time of Final Site Clearance. The waste is assumed to be in baskets in the waste package so the

occupied volume in the package is greater than the original waste volume.

Range in container waste

volume:

Not yet determined. No significant variability is expected.

Other information on

containers:

The container material is expected to be stainless steel.

Likely conditioning matrix:

Other information:

Blast Furnace Slag / Ordinary Portland Cement The waste is assumed to be encapsulated.

~1.7 Conditioned density (t/m³):

Conditioned density

comment:

The conditioned waste density assumes that the waste will be encapsulated.

Other information on

conditioning:

The waste will be in baskets placed in the waste packages. Baskets of different Final Dismantling & Site Clearance ILW wastes may be in the same waste package. The encapsulation matrix is likely to be BFS/OPC. Data have been presented as if the waste

will be placed in a container with other ILW.

Opportunities for alternative

disposal routing:

Opportunity	Opportunity Confidence Comment
-------------	--------------------------------

RADIOACTIVITY

Source: Activation of the graphite and impurities.

Uncertainty: The values quoted were derived by calculation from available material specification and

are indicative of the activities that are expected. The major source of uncertainty is the

impurity levels.

Definition of total alpha and total beta/gamma:

Where totals are shown on the table of radionuclide activities they are the sums of the listed alpha or beta/gamma emitting radionuclides plus 'other alpha' or 'other beta/gamma'.

Measurement of radioactivities:

The specific activities were estimated from neutron activation calculations of the material and its impurities. With additional data from newly calculated inventories including 100 ppb

U precursor as per M/EF/GEN/EAN/0008/20

Other information: The activities quoted are those at 85 years after reactor shutdown. There may be some

contamination by Cs137. Fission of trace uranium impurity in the graphite may result in

some fission product and actinide activity.

WASTE STREAM Graphite ILW 9H311

	Mean radioactivity, TBq/m³			Mean radioactivity, TBq/m³					
Nuclide	Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code	Nuclide	Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code
H 3			2.88E-03	CC 2	Gd 153				8
Be 10				8	Ho 163				8
C 14			1.6E-01	BB 2	Ho 166m			4.17E-06	CC 2
Na 22				8	Tm 170				8
AI 26				8	Tm 171				8
CI 36			3.5E-04	CC 2	Lu 174				8
Ar 39				8	Lu 176				8
Ar 42				8	Hf 178n				8
K 40				8	Hf 182				8
Ca 41			4.1E-04	CC 2	Pt 193				8
Mn 53				8	TI 204				8
Mn 54				8	Pb 205				8
Fe 55				8	Pb 210				8
Co 60			7.77E-06	CC 2	Bi 208				8
Ni 59			4.13E-05	CC 2	Bi 210m				8
Ni 63			3.23E-03	CC 2	Po 210				8
Zn 65	Ì			8	Ra 223				8
Se 79				8	Ra 225				8
Kr 81				8	Ra 226				8
Kr 85			8.76E-07	CC 2	Ra 228				8
Rb 87				8	Ac 227				8
Sr 90			2.76E-04	CC 2	Th 227				8
Zr 93			7.9E-08	CC 2	Th 228				8
Nb 91				8	Th 229				8
Nb 92				8	Th 230				8
Nb 93m			7.59E-08	CC 2	Th 232				8
Nb 94			4.83E-07	CC 2	Th 234				8
Mo 93				8	Pa 231				8
Tc 97				8	Pa 233			1.05E-09	CC 2
Tc 99			4.94E-07	CC 2	U 232				8
Ru 106				8	U 233				8
Pd 107			7.4E-09	CC 2	U 234			6.29E-09	CC 2
Ag 108m			5.29E-06	CC 2	U 235				8
Ag 110m			0.202 00	8	U 236				8
Cd 109				8	U 238				8
Cd 113m				8	Np 237			1.05E-09	CC 2
Sn 119m				8	Pu 236				8
Sn 121m			2.66E-04	CC 2	Pu 238			1.59E-05	CC 2
Sn 123				8	Pu 239			1.72E-06	CC 2
Sn 126			2.98E-08	CC 2	Pu 240			1.52E-05	CC 2
Sb 125			2.002 00	8	Pu 241			1.96E-05	CC 2
Sb 126			4.16E-09		Pu 242	Ī		2.15E-07	CC 2
Te 125m	İ			8	Am 241			3.65E-05	CC 2
Te 127m				8	Am 242m			4.16E-08	CC 2
I 129				8	Am 243			5.43E-06	CC 2
Cs 134				8	Cm 242			3.45E-08	CC 2
Cs 134			2.23E-08	CC 2	Cm 243			5.29E-08	CC 2
Cs 137			5.43E-04	CC 2	Cm 244	i		1.58E-04	CC 2
Ba 133	i		7.77E-07	CC 2	Cm 245			3.2E-07	CC 2
La 137			7.772-07	8	Cm 246			2.3E-06	CC 2
La 137				8	Cm 248			2.52 00	8
Ce 144				8	Cf 249			7.56E-09	CC 2
Pm 145			2.88E-07	CC 2	Cf 250			1.23E-09	CC 2
			∠.00⊏-∪/		Cf 250 Cf 251			1.232-03	
Pm 147				8	Cf 251 Cf 252				8 8
Sm 147			2.045.00	8					O
Sm 151			3.01E-06	CC 2	Other a				
Eu 152			1.81E-07	CC 2	Other b/g	_		2.265.04	CC 2
Eu 154	-		8.52E-07	CC 2	Total a	0		2.36E-04	CC 2
Eu 155			3.04E-09	CC 2	Total b/g	0		1.68E-01	CC 2

Bands (Upper and Lower)

A a factor of 1.5 B a factor of 3

C a factor of 10

D a factor of 100

E a factor of 1000

Note: Bands quantify uncertainty in mean radioactivity.

- Measured activity
 Derived activity (best estimate)
 Derived activity (upper limit)
- 4 Not present
- 5 Present but not significant
- 6 Likely to be present but not assessed
- 7 Present in significant quantities but not determined
- 8 Not expected to be present in significant quantity