

WASTE STREAM	9J321	Thermal Insulation (Asbestos) LLW
---------------------	--------------	------------------------------------------

SITE Hunterston A
SITE OWNER Nuclear Decommissioning Authority

WASTE CUSTODIAN Magnox Limited

WASTE TYPE LLW

Is the waste subject to Scottish Policy: No

WASTE VOLUMES

		Reported
Stocks:	At 1.4.2022.....	0 m ³
Future arisings -	1.4.2075 - 31.3.2080.....	1548.0 m ³
Total future arisings:		1548.0 m ³
Total waste volume:		1548.0 m ³

Comment on volumes: Arisings are assumed to arise at a uniform rate over 5 years. Final Dismantling & Site Clearance is assumed to commence in 2071 with reactor dismantling commencing in 2075 and lasting for 5 years. The volumes and radioactivity have been calculated for 85 years after reactor shutdown, i.e. 2075.

Uncertainty factors on volumes: Stock (upper): x Arisings (upper) x 1.2
 Stock (lower): x Arisings (lower) x 0.8

WASTE SOURCE Insulation materials from active plant dismantling.

PHYSICAL CHARACTERISTICS

General description: Insulation materials.
 Physical components (%wt): The waste consists of insulation materials (100%wt).
 Sealed sources: The waste does not contain sealed sources.
 Bulk density (t/m³): ~1
 Comment on density: The density is of the raw waste.

CHEMICAL COMPOSITION

General description and components (%wt): Pressure vessel insulation (100%wt)
 Chemical state: Neutral
 Chemical form of radionuclides: H-3: The chemical form of tritium has not been assessed, but may be incorporated into the steel.
 C-14: The chemical form of carbon 14 has not been assessed but may be graphite.
 Cl-36: The chemical form of chlorine 36 has not been assessed.
 Se-79: The selenium-79 content is insignificant.
 Tc-99: The technetium-99 content is insignificant.
 Ra: The radium content is insignificant.
 Th: The thorium content is insignificant.
 U: The uranium content is insignificant.
 Np: The neptunium isotope content is insignificant.
 Pu: The plutonium content is insignificant.

Metals and alloys (%wt): -

	(%wt)	Type(s) / Grade(s) with proportions	% of total C14 activity
Stainless steel.....	0		
Other ferrous metals.....	0		
Iron.....			
Aluminium.....			
Beryllium.....			
Cobalt.....			

WASTE STREAM	9J321	Thermal Insulation (Asbestos) LLW
---------------------	--------------	------------------------------------------

Copper.....
 Lead.....
 Magnox/Magnesium.....
 Nickel.....
 Titanium.....
 Uranium.....
 Zinc.....
 Zircaloy/Zirconium.....
 Other metals.....

Organics (%wt): -

	(%wt)	Type(s) and comment	% of total C14 activity
Total cellulose	0		
Paper, cotton	0		
Wood	0		
Halogenated plastics			
Total non-halogenated plastics	0		
Condensation polymers			
Others			
Organic ion exchange materials	0		
Total rubber	0		
Halogenated rubber	0		
Non-halogenated rubber	0		
Hydrocarbons			
Oil or grease			
Fuel			
Asphalt/Tarmac (cont.coal tar)			
Asphalt/Tarmac (no coal tar)			
Bitumen			
Others			
Other organics	0		

Other materials (%wt): -

	(%wt)	Type(s) and comment	% of total C14 activity
Inorganic ion exchange materials	0		
Inorganic sludges and flocs			
Soil	0		
Brick/Stone/Rubble	0		
Cementitious material			
Sand			
Glass/Ceramics	100.0	MMMF (Man Made Mineral Fibre) insulation material	100.0
Graphite			
Desiccants/Catalysts			

WASTE STREAM	9J321	Thermal Insulation (Asbestos) LLW
---------------------	--------------	------------------------------------------

Asbestos.....	NE
Non/low friable.....	NE
Moderately friable.....	NE
Highly friable.....	NE
Free aqueous liquids.....	0
Free non-aqueous liquids.....	0
Powder/Ash.....	0

Inorganic anions (%wt): -

	(%wt)	Type(s) and comment
Fluoride.....	NE	
Chloride.....	NE	
Iodide.....	NE	
Cyanide.....	0	
Carbonate.....	NE	
Nitrate.....	NE	
Nitrite.....	NE	
Phosphate.....	NE	
Sulphate.....	NE	
Sulphide.....	NE	

Materials of interest for waste acceptance criteria: The presence or absence of asbestos has yet to be confirmed.

	(%wt)	Type(s) and comment
Combustible metals.....	0	
Low flash point liquids.....	0	
Explosive materials.....	0	
Phosphorus.....	0	
Hydrides.....	0	
Biological etc. materials.....	0	
Biodegradable materials.....		
Putrescible wastes.....	0	
Non-putrescible wastes.....		
Corrosive materials.....	0	
Pyrophoric materials.....	0	
Generating toxic gases.....	0	
Reacting with water.....	0	
Higher activity particles.....		
Soluble solids as bulk chemical compounds.....		

Hazardous substances / non hazardous pollutants: -

	(%wt)	Type(s) and comment
Acrylamide.....		

- Benzene.....
- Chlorinated solvents.....
- Formaldehyde.....
- Organometallics.....
- Phenol.....
- Styrene.....
- Tri-butyl phosphate.....
- Other organophosphates.....
- Vinyl chloride.....
- Arsenic.....
- Barium.....
- Boron.....
 - Boron (in Boral).....
 - Boron (non-Boral).....
- Cadmium.....
- Caesium.....
- Selenium.....
- Chromium.....
- Molybdenum.....
- Thallium.....
- Tin.....
- Vanadium.....
- Mercury compounds.....
- Others.....
- Electronic Electrical Equipment (EEE)
 - EEE Type 1.....
 - EEE Type 2.....
 - EEE Type 3.....
 - EEE Type 4.....
 - EEE Type 5.....

Complexing agents (%wt): Yes

(%wt) Type(s) and comment

- EDTA.....
- DPTA.....
- NTA.....
- Polycarboxylic acids.....
- Other organic complexants.....
- Total complexing agents..... TR

Potential for the waste to contain discrete items:

No. In & of itself not a DI. If LLW then assumed drummed (ungroued) & compacted so NOT DI (unless drums are groued instead).

WASTE STREAM

9J321

Thermal Insulation (Asbestos) LLW

TREATMENT, PACKAGING AND DISPOSAL

Planned on-site / off-site treatment(s):

Treatment	On-site / Off site	Stream volume %
Low force compaction Supercompaction (HFC) Incineration Solidification Decontamination Metal treatment Size reduction Decay storage Recycling / reuse Other / various None		100.0

Comment on planned treatments:

-

Disposal Routes:

Disposal Route	Stream volume %	Disposal density t/m3
Expected to be consigned to the LLW Repository Expected to be consigned to a Landfill Facility Expected to be consigned to an On-Site Disposal Facility Expected to be consigned to an Incineration Facility Expected to be consigned to a Metal Treatment Facility Expected to be consigned as Out of Scope Expected to be recycled / reused Disposal route not known	100.0	1.0

Classification codes for waste expected to be consigned to a landfill facility: 17 06 01*, 17 06 03*, 17 06 04

Upcoming (2022/23-2024/25) Waste Routing (if expected to change from above):

Disposal Route	Stream volume %		
	2022/23	2023/24	2024/25
Expected to be consigned to the LLW Repository Expected to be consigned to a Landfill Facility Expected to be consigned to an On-Site Disposal Facility Expected to be consigned to an Incineration Facility Expected to be consigned to a Metal Treatment Facility Expected to be consigned as Out of Scope Expected to be recycled / reused Disposal route not known			

Opportunities for alternative disposal routing: -

Baseline Management Route	Opportunity Management Route	Stream volume (%)	Estimated Date that Opportunity will be realised	Opportunity Confidence	Comment
-	-	-	-	-	-

Waste Packaging for Disposal: (Not applicable to this waste stream)

WASTE STREAM**9J321****Thermal Insulation (Asbestos) LLW**

Container	Stream volume %	Waste loading m ³	Number of packages
1/3 Height IP-1 ISO			
2/3 Height IP-2 ISO			
1/2 Height WAMAC IP-2 ISO			
1/2 Height IP-2 Disposal/Re-usable ISO			
2m box (no shielding)			
4m box (no shielding)			
Other			

Other information: -

Waste Planned for Disposal at the LLW Repository: (Not applicable to this waste stream)

Container voidage: -

Waste Characterisation Form (WCH): -

Waste consigned for disposal to LLWR in year of generation: -

Non-Containerised Waste for In-Vault Grouting: (Not applicable to this waste stream)

Stream volume (%): -

Waste stream variation: -

Bounding cuboidal volume:

Inaccessible voidage: -

Other information: -

RADIOACTIVITY

Source: Activation of the materials and impurities. There may be some contamination.

Uncertainty: Only very approximate estimates have been made of the total specific activities. The activities quoted are those at the time of Final Dismantling & Site Clearance (about 85 years after Station shutdown).

Definition of total alpha and total beta/gamma: Where totals are shown on the table of radionuclide activities they are the sums of the listed alpha or beta/gamma emitting radionuclides plus 'other alpha' or 'other beta/gamma'.

Measurement of radioactivities: The specific activity of the reactor thermal insulation was assumed to be similar to that for Trawsfynydd.

Other information: -

WASTE STREAM 9J321 Thermal Insulation (Asbestos) LLW

Nuclide	Mean radioactivity, TBq/m ³				Nuclide	Mean radioactivity, TBq/m ³			
	Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code		Waste at 1.4.2022	Bands and Code	Future arisings	Bands and Code
H 3			3.7E-05	CC 2	Gd 153				8
Be 10				8	Ho 163				8
C 14			7.13E-05	CC 2	Ho 166m				8
Na 22				8	Tm 170				8
Al 26			1E-06	CC 2	Tm 171				8
Cl 36			1.18E-06	CC 2	Lu 174				8
Ar 39				8	Lu 176				8
Ar 42				8	Hf 178n				8
K 40				8	Hf 182				8
Ca 41			1.56E-05	CC 2	Pt 193				8
Mn 53				8	Tl 204				8
Mn 54				8	Pb 205				8
Fe 55				8	Pb 210				8
Co 60			2.83E-08	CC 2	Bi 208				8
Ni 59				8	Bi 210m				8
Ni 63			2.73E-05	CC 2	Po 210				8
Zn 65				8	Ra 223				8
Se 79				8	Ra 225				8
Kr 81				8	Ra 226				8
Kr 85				8	Ra 228				8
Rb 87				8	Ac 227				8
Sr 90				8	Th 227				8
Zr 93				8	Th 228				8
Nb 91				8	Th 229				8
Nb 92				8	Th 230				8
Nb 93m				8	Th 232				8
Nb 94			1.53E-09	CC 2	Th 234				8
Mo 93			1.23E-08	CC 2	Pa 231				8
Tc 97				8	Pa 233				8
Tc 99				8	U 232				8
Ru 106				8	U 233				8
Pd 107				8	U 234				8
Ag 108m				8	U 235				8
Ag 110m				8	U 236				8
Cd 109				8	U 238				8
Cd 113m				8	Np 237				8
Sn 119m				8	Pu 236				8
Sn 121m			1.18E-08	CC 2	Pu 238				8
Sn 123				8	Pu 239				8
Sn 126				8	Pu 240				8
Sb 125				8	Pu 241				8
Sb 126				8	Pu 242				8
Te 125m				8	Am 241				8
Te 127m				8	Am 242m				8
I 129				8	Am 243				8
Cs 134				8	Cm 242				8
Cs 135				8	Cm 243				8
Cs 137				6	Cm 244				8
Ba 133			2.68E-08	CC 2	Cm 245				8
La 137				8	Cm 246				8
La 138				8	Cm 248				8
Ce 144				8	Cf 249				8
Pm 145				8	Cf 250				8
Pm 147				8	Cf 251				8
Sm 147				8	Cf 252				8
Sm 151			1.89E-06	CC 2	Other a				
Eu 152			8.83E-06	CC 2	Other b/g				
Eu 154			1.4E-07	CC 2	Total a	0		0	
Eu 155				8	Total b/g	0		1.64E-04	CC 2

Bands (Upper and Lower)

- A a factor of 1.5
- B a factor of 3
- C a factor of 10
- D a factor of 100
- E a factor of 1000

Note: Bands quantify uncertainty in mean radioactivity.

Code

- 1 Measured activity
- 2 Derived activity (best estimate)
- 3 Derived activity (upper limit)
- 4 Not present
- 5 Present but not significant
- 6 Likely to be present but not assessed
- 7 Present in significant quantities but not determined
- 8 Not expected to be present in significant quantity